



BALL CORPORATION - ZEPHYR WIND PROJECT

North Findlay Wind Campus, Findlay, OH




A. Site Energy Production Summary

Energy Production (kWh)					
Site		By Turbine			
	P50 (Expected Production)	Actual Production	Z1	Z2	Z3
Jun-19	628,000	682,994	232,437	224,872	225,685
Jul-19	571,000	469,744	167,832	151,963	149,949
Aug-19	598,000	513,686	177,673	167,452	168,561
Sep-19	515,000	585,768	205,203	193,838	186,727
Oct-19	966,000	1,039,656	350,721	348,791	340,144
Nov-19	1,262,000	889,667	312,289	296,145	281,233
Dec-19	1,524,000	1,392,651	483,293	460,120	449,238
Jan-20	1,291,000	1,187,158	410,228	396,206	380,724
Feb-20	1,355,000	963,876	349,562	308,005	306,309
Mar-20	1,197,000	1,162,213	396,502	388,972	376,739
Apr-20	1,415,000	1,077,278	363,770	357,740	355,768
May-20	900,000	924,506	311,078	306,313	307,115
Jun-20	628,000	745,225	255,090	244,089	246,046
Production 2020 (ytd) (kWh)	6,786,000	6,060,256	2,086,230	2,001,325	1,972,701
Total Production (kWh)*	12,222,000	10,951,428	3,783,241	3,619,634	3,548,553
Capacity Factor*	27.71%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

June-2020



Monthly Report

June-2020

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2020	Goldwind 4.5 Year Maintenance	~8	Z1
October-2020	Goldwind 4.5 Year Maintenance	~8	Z2
October-2020	Goldwind 4.5 Year Maintenance	~8	Z3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
6/8/2020	Owner/Operator Inspection	Unplanned	4.03	Z1
6/16/2020	Owner/Operator Maintenance	Unplanned	6.39	Z3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
Z1	99.97%	99.84%
Z2	99.92%	99.98%
Z3	100.00%	100.00%
Avg	99.96%	99.94%

Downtime (hr)	This Month	Year To Date
Z1	5.78	91.90
Z2	2.10	125.25
Z3	7.93	107.16
Total	15.81	324.31

G. Billed Data

Meter Reading (Date/Time)	6/18/2020 12:00 AM
Meter To Date Produced	49,018,388 kWh
Meter To Date Consumed	60,465 kWh
Last Reading Produced	48,226,722 kWh
Last Reading Consumed	59,694 kWh
Billed kWh	790,895 kWh
Next Meter Reading	7/18/2020 12:00 AM

H. Report Notes and Comments

*Z3 production total for May and June 2019 is an estimate due to loss of communications.