


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Jun-19	422,000	474,817	240,372	234,445
Jul-19	383,000	338,373	171,861	166,512
Aug-19	402,000	355,979	180,172	175,807
Sep-19	346,000	403,384	203,853	199,531
Oct-19	649,000	709,389	354,865	354,524
Nov-19	846,000	669,872	338,584	331,288
Dec-19	1,022,000	943,766	481,616	462,150
Jan-20	867,000	820,679	407,059	413,620
Feb-20	908,000	670,274	317,389	352,885
Mar-20	803,000	795,295	400,369	394,926
Apr-20	949,000	706,174	357,900	348,274
May-20	603,000	633,162	322,304	310,858
Jun-20	422,000	512,907	257,351	255,556
Production 2020 (ytd) (kWh)	4,552,000	4,138,491	2,062,372	2,076,119
Total Production (kWh)*	8,200,000	7,559,254	3,793,323	3,765,931
Capacity Factor*	28.69%		*Value calculated over the last 12 months	

B. Site Energy Production Graph

June-2020



Monthly Report

June-2020

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2020	Goldwind 5 Year Maintenance	~15	W1
October-2020	Goldwind 5 Year Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.94%
W2	99.97%	99.93%
Avg	99.99%	99.94%

Downtime (hr)	This Month	Year To Date
W1	2.85	184.16
W2	1.75	72.58
Total	4.60	256.74

G. Billed Data

Meter Reading (Date/Time)	6/29/2020 12:00 AM
Meter To Date Produced	34,691,099 kWh
Meter To Date Consumed	68,910 kWh
Last Reading Produced	34,158,319 kWh
Last Reading Consumed	67,645 kWh
Billed kWh	531,515 kWh
Next Meter Reading	7/29/2020 12:00 AM

H. Report Notes and Comments