




A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG A	WTG B	WTG C
Jul-19	638,097	575,390	191,700	191,910	191,780
Aug-19	577,992	634,650	218,690	210,230	205,730
Sep-19	631,697	732,500	253,580	232,050	246,870
Oct-19	1,003,602	1,248,994	421,770	423,766	403,458
Nov-19	1,395,914	1,124,700	383,460	368,940	372,300
Dec-19	1,278,858	1,370,840	492,520	451,610	426,710
Jan-20	1,332,437	1,346,410	458,880	440,070	447,460
Feb-20	1,157,019	1,226,310	419,290	406,120	400,900
Mar-20	1,242,761	1,324,950	450,850	430,520	443,580
Apr-20	1,447,248	1,232,926	423,174	392,024	417,728
May-20	1,010,966	1,138,690	392,230	364,170	382,290
Jun-20	668,411	886,190	306,680	297,480	282,030
Jul-20	638,097	470,790	162,000	144,430	164,360
Production 2020 (ytd) (kWh)	7,496,937	7,626,266	2,613,104	2,474,814	2,538,348
Total Production (kWh)*	12,384,999	12,737,950	4,383,124	4,161,410	4,193,416
Capacity Factor*	32.23%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

July-2020



Monthly Report
July-2020



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2020	Goldwind 8 Year Maintenance	~15	WTG A
September-2020	Goldwind 8 Year Maintenance	~15	WTG B
September-2020	Goldwind 8 Year Maintenance	~15	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
7/9/2020	Pitch Motor Inspection	Unplanned	4.28	WTG B
7/10-13/2020	Tower Base Cooling Fan Error	Unplanned	62.41	WTG B
7/22/2020	Customer Shutdown	Unplanned	7.46	WTG A
7/22/2020	Customer Shutdown	Unplanned	4.95	WTG B
7/22/2020	Customer Shutdown	Unplanned	4.94	WTG C

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WTG A	100.00%	100.00%
WTG B	93.96%	98.88%
WTG C	100.00%	99.82%
Avg	97.99%	99.57%

Downtime (hr)	This Month	Year To Date
WTG A	9.55	48.66
WTG B	76.48	136.73
WTG C	8.55	108.00
Total	94.58	293.39

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2020 Annual
WTG A	8.47	11.84
WTG B	8.60	11.80
WTG C	9.24	12.58
Estimated	11.22	13.39

Capacity Factor (%)	This Month	2020 Annual
WTG A	14.52%	34.08%
WTG B	12.94%	32.27%
WTG C	14.73%	33.10%
Low Estimate	18.03%	28.72%

H. Report Notes and Comments