


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Jul-19	383,000	338,373	171,861	166,512
Aug-19	402,000	355,979	180,172	175,807
Sep-19	346,000	403,384	203,853	199,531
Oct-19	649,000	709,389	354,865	354,524
Nov-19	846,000	669,872	338,584	331,288
Dec-19	1,022,000	943,766	481,616	462,150
Jan-20	867,000	820,679	407,059	413,620
Feb-20	908,000	670,274	317,389	352,885
Mar-20	803,000	795,295	400,369	394,926
Apr-20	949,000	706,174	357,900	348,274
May-20	603,000	633,162	322,304	310,858
Jun-20	422,000	512,907	257,351	255,556
Jul-20	390,000	317,320	159,723	157,597
Production 2020 (ytd) (kWh)	4,942,000	4,455,811	2,222,095	2,233,716
Total Production (kWh)*	8,207,000	7,538,201	3,781,185	3,757,016
Capacity Factor*	28.61%		*Value calculated over the last 12 months	

B. Site Energy Production Graph

July-2020



Monthly Report July-2020

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2020	Goldwind 5 Year Maintenance	~15	W1
October-2020	Goldwind 5 Year Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.95%
W2	100.00%	99.94%
Avg	100.00%	99.95%

Downtime (hr)	This Month	Year To Date
W1	1.71	185.87
W2	2.04	74.62
Total	3.75	260.49

G. Billed Data

Meter Reading (Date/Time)	7/29/2020 12:00 AM
Meter To Date Produced	34,975,170 kWh
Meter To Date Consumed	71,101 kWh
Last Reading Produced	34,691,099 kWh
Last Reading Consumed	68,910 kWh
Billed kWh	281,880 kWh
Next Meter Reading	8/29/2020 12:00 AM

H. Report Notes and Comments