


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Jul-19	201,000	166,408
Aug-19	211,000	188,300
Sep-19	182,000	205,853
Oct-19	341,000	395,663
Nov-19	445,000	329,892
Dec-19	537,000	480,035
Jan-20	455,000	427,899
Feb-20	478,000	353,172
Mar-20	422,000	413,290
Apr-20	499,000	397,381
May-20	318,000	346,599
Jun-20	222,000	262,997
Jul-20	201,000	158,687
Production 2020 (ytd) (kWh)	2,595,000	2,360,025
Total Production (kWh)*	4,311,000	3,959,768
Capacity Factor*	30.05%	

*Value calculated over the last 12 months

B. Site Energy Production Graph

July-2020



Monthly Report July-2020

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2020	Goldwind 2.5 Year Maintenance	~8	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.69%
Downtime (hr)	This Month	Year To Date
W1	4.16	131.23

G. Billed Data

Meter Reading (Date/Time)	8/1/2020 12:00 AM
Meter To Date Produced	9,649,771 kWh
Meter To Date Consumed	48,765 kWh
Last Reading Produced	9,493,897 kWh
Last Reading Consumed	46,442 kWh
Billed kWh	153,551 kWh
Next Meter Reading	9/1/2020 12:00 AM

H. Report Notes and Comments