



HARPSTER WIND PROJECT

Harpster, OH


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Sep-19	224,000	155,481
Oct-19	338,000	316,812
Nov-19	402,000	289,819
Dec-19	403,000	406,815
Jan-20	460,000	370,564
Feb-20	372,000	292,978
Mar-20	417,000	359,827
Apr-20	399,000	351,248
May-20	311,000	301,340
Jun-20	228,000	211,118
Jul-20	179,000	127,434
Aug-20	157,000	119,753
Sep-20	224,000	194,360
Production 2020 (ytd) (kWh)	2,747,000	2,328,622
Total Production (kWh)*	3,890,000	3,342,068
Capacity Factor*	25.36%	

*Value calculated over the last 12 months

B. Site Energy Production Graph

September-2020



Monthly Report

September-2020



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2020	Goldwind 4.5 Year Maintenance	~8	H1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
H1	100.00%	99.84%
Downtime (hr)	This Month	Year To Date
H1	4.51	153.71

G. Billed Data

Meter Reading (Date/Time)	9/24/2020 12:00 AM
Meter To Date Produced	15,012,905 kWh
Meter To Date Consumed	53,112 kWh
Last Reading Produced	14,836,206 kWh
Last Reading Consumed	52,195 kWh
Billed kWh	175,782 kWh
Next Meter Reading	10/23/2020 12:00 AM

H. Report Notes and Comments