


A. Site Energy Production Summary*

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Oct-19	649,000	709,389	354,865	354,524
Nov-19	846,000	669,872	338,584	331,288
Dec-19	1,022,000	943,766	481,616	462,150
Jan-20	867,000	820,679	407,059	413,620
Feb-20	908,000	670,274	317,389	352,885
Mar-20	803,000	795,295	400,369	394,926
Apr-20	949,000	706,174	357,900	348,274
May-20	603,000	633,162	322,304	310,858
Jun-20	422,000	512,907	257,351	255,556
Jul-20	383,000	317,320	159,723	157,597
Aug-20	399,000	300,935	157,115	143,820
Sep-20	337,000	489,578	244,573	245,005
Oct-20	637,000	603,877	306,458	297,419
Production 2020 (ytd) (kWh)	6,308,000	5,850,201	2,930,241	2,919,960
Total Production (kWh)*	8,176,000	7,463,839	3,750,441	3,713,398
Capacity Factor*	28.32%		*Value calculated over the last 12 months	

B. Site Energy Production Graph

October-2020



Monthly Report

October-2020

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2021	Goldwind 5.5 Year Maintenance	~8	W1
April-2021	Goldwind 5.5 Year Maintenance	~8	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
10/14/2020	Goldwind 5 Year Maintenance	Planned	3.26	W1
10/14/2020	Goldwind 5 Year Maintenance	Planned	3.61	W2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.96%
W2	100.00%	99.45%
Avg	100.00%	99.71%

Downtime (hr)	This Month	Year To Date
W1	4.93	204.57
W2	6.95	131.75
Total	11.88	336.32

G. Billed Data

Meter Reading (Date/Time)	10/29/2020 12:00 AM
Meter To Date Produced	36,353,397 kWh
Meter To Date Consumed	75,029 kWh
Last Reading Produced	35,737,546 kWh
Last Reading Consumed	73,904 kWh
Billed kWh	614,726 kWh
Next Meter Reading	11/29/2020 12:00 AM

H. Report Notes and Comments

*Change in production estimate due to Material Change of Circumstance.