


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Oct-19	1,051,000	1,033,402	351,806	342,691	338,905
Nov-19	1,224,000	869,845	297,447	287,622	284,776
Dec-19	1,217,000	1,216,234	461,480	437,079	317,675
Jan-20	1,343,000	966,360	362,196	344,267	259,897
Feb-20	1,133,000	849,494	298,415	266,192	284,887
Mar-20	1,312,000	1,215,269	410,779	403,277	401,213
Apr-20	1,272,000	1,065,044	362,884	353,029	349,131
May-20	974,000	947,249	320,883	304,086	322,280
Jun-20	714,000	616,108	211,039	201,746	203,323
Jul-20	566,000	359,627	122,783	118,871	117,973
Aug-20	514,000	352,591	121,092	114,292	117,207
Sep-20	716,000	646,411	223,263	209,399	213,749
Oct-20	1,051,000	889,528	302,399	297,007	290,122
Production 2020 (ytd) (kWh)	9,595,000	7,907,681	2,735,733	2,612,166	2,559,782
Total Production (kWh)*	12,036,000	9,993,760	3,494,660	3,336,867	3,162,233
Capacity Factor*	25.28%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

October-2020



Monthly Report
October-2020

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2021	Goldwind 2.5 Year Maintenance	~8	WG 1
April-2021	Goldwind 2.5 Year Maintenance	~8	WG 2
April-2021	Goldwind 2.5 Year Maintenance	~8	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
10/28/2020	Goldwind 2 Year Maintenance	Planned	2.60	WG 1
10/28/2020	Goldwind 2 Year Maintenance	Planned	2.36	WG 2
10/30/2020	Goldwind 2 Year Maintenance	Planned	2.03	WG 3

F. Turbine Availability & Downtime**

Availability	This Month	Year To Date
WG1	100.00%	100.00%
WG2	100.00%	100.00%
WG3	100.00%	99.99%
Avg	100.00%	100.00%

Downtime (hr)	This Month	Year To Date
WG1	3.63	208.24
WG2	3.36	238.00
WG3	3.58	326.88
Total	10.57	773.12

G. Billed Data

Meter Reading (Date/Time)	10/29/2020 12:00 AM
Meter To Date Produced	20,386,331 kWh
Meter To Date Consumed	89,198 kWh
Last Reading Produced	19,549,881 kWh
Last Reading Consumed	86,163 kWh
Billed kWh	833,415 kWh
Next Meter Reading	11/29/2020 12:00 AM

H. Report Notes and Comments

*WG3 production for December 2019 and January 2020 is an estimate due to communication issue.
**After review, reported September Downtime and availability was accurate.