


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	W1	W2	W3
Oct-19	990,000	916,038	308,623	294,939	312,476
Nov-19	1,123,000	846,849	291,098	273,259	282,492
Dec-19	1,153,000	1,139,609	398,017	365,419	376,173
Jan-20	1,306,000	1,063,984	370,096	346,270	347,618
Feb-20	1,137,000	767,713	286,395	246,834	234,484
Mar-20	1,134,000	1,101,462	378,775	354,544	368,143
Apr-20	1,176,000	1,028,204	354,270	335,252	338,682
May-20	927,000	863,616	293,660	275,555	294,401
Jun-20	634,000	542,111	193,735	179,058	169,318
Jul-20	527,000	307,801	107,383	97,517	102,901
Aug-20	449,000	319,596	107,014	102,774	109,808
Sep-20	610,000	609,440	202,193	196,981	210,266
Oct-20	990,000	736,506	247,147	240,678	248,681
Production 2020 (ytd) (kWh)	8,890,000	7,340,433	2,540,668	2,375,463	2,424,302
Total Production (kWh)*	11,166,000	9,326,891	3,229,783	3,014,141	3,082,967
Capacity Factor*	23.60%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

October-2020



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events8

Date	Event	Duration (hr)	Turbine
April-2021	Goldwind 3.5 Year Maintenance	~8	W1
April-2021	Goldwind 3.5 Year Maintenance	~8	W2
April-2021	Goldwind 3.5 Year Maintenance	~8	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
10/9/2020	Goldwind 3 Year Maintenance	Planned	1.82	W1
10/13/2020	Goldwind 3 Year Maintenance	Planned	2.50	W2
10/13/2020	Goldwind 3 Year Maintenance	Planned	3.94	W3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.97%
W2	100.00%	99.86%
W3	100.00%	99.46%
Avg	100.00%	99.76%

Downtime (hr)	This Month	Year To Date
W1	1.82	262.11
W2	2.50	305.95
W3	3.94	397.00
Total	8.26	965.06

G. Billed Data

Meter Reading (Date/Time)	10/21/2020 12:00 AM
Meter To Date Produced	26,634,001 kWh
Meter To Date Consumed	83,270 kWh
Last Reading Produced	25,940,291 kWh
Last Reading Consumed	81,349 kWh
Billed kWh	691,789 kWh
Next Meter Reading	11/21/2020 12:00 AM

H. Report Notes and Comments