


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Oct-19	341,000	395,663
Nov-19	445,000	329,892
Dec-19	537,000	480,035
Jan-20	455,000	427,899
Feb-20	478,000	353,172
Mar-20	422,000	413,290
Apr-20	499,000	397,381
May-20	318,000	346,599
Jun-20	222,000	262,997
Jul-20	201,000	158,687
Aug-20	211,000	159,430
Sep-20	182,000	251,972
Oct-20	341,000	341,043
Production 2020 (ytd) (kWh)	3,329,000	3,112,470
Total Production (kWh)*	4,311,000	3,922,397
Capacity Factor*	29.77%	

*Value calculated over the last 12 months

B. Site Energy Production Graph

October-2020



Monthly Report
October-2020

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
March-2021	Goldwind 3 Year Maintenance	~15	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.78%

Downtime (hr)	This Month	Year To Date
W1	1.18	141.70

G. Billed Data

Meter Reading (Date/Time)	11/1/2020 12:00 AM
Meter To Date Produced	10,390,557 kWh
Meter To Date Consumed	53,170 kWh
Last Reading Produced	10,054,178 kWh
Last Reading Consumed	51,916 kWh
Billed kWh	335,125 kWh
Next Meter Reading	12/1/2020 12:00 AM

H. Report Notes and Comments