


A. Site Energy Production Summary\*

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Aug-20	534,000	251,447	74,850	95,169	81,428
Sep-20	736,000	700,759	241,924	248,089	210,746
Oct-20	1,131,000	977,504	330,212	329,167	318,125
Nov-20	1,281,000	1,381,160	464,646	463,381	453,133
Dec-20	1,263,000				
Jan-21	1,433,000				
Feb-21	1,213,000				
Mar-21	1,339,000				
Apr-21	1,327,000				
May-21	1,052,000				
Jun-21	751,000				
Jul-21	609,000				
Aug-21	534,000				
Production 2020 (ytd) (kWh)	3,682,000	3,310,870	1,111,632	1,135,806	1,063,432
Total Production (kWh)*	-	-	-	-	-
Capacity Factor*	- *Value calculated over the last 12 months				

B. Site Energy Production Graph

November-2020



Monthly Report

November-2020

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
February-2021	Goldwind 6 Month Maintenance	~8	L1
February-2021	Goldwind 6 Month Maintenance	~8	L2
February-2021	Goldwind 6 Month Maintenance	~8	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
11/15/2020	Weather Shutdown	Unplanned	8.47	L1
11/15/2020	Weather Shutdown	Unplanned	8.47	L2
11/15/2020	Weather Shutdown	Unplanned	8.47	L3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	100.00%	99.44%
L2	99.88%	99.51%
L3	100.00%	97.45%
Avg	99.96%	98.80%

Downtime (hr)	This Month	Year To Date
L1	13.69	37.07
L2	14.14	34.90
L3	13.36	76.84
Total	41.19	148.81

G. Billed Data

Meter Reading (Date/Time)	11/21/2020 12:00 AM
Meter To Date Produced	2,979,861 kWh
Meter To Date Consumed	11,451 kWh
Last Reading Produced	1,690,305 kWh
Last Reading Consumed	9,497 kWh
Billed kWh	1,287,602 kWh
Next Meter Reading	12/24/2020 12:00 AM

H. Report Notes and Comments

\*Capacity factor to be included once full year of data is available.