

# **Holcim - Paulding Wind Project**


LafargeHolcim Holcim - Paulding Wind Project, Paulding, Ohio

# A. Site Energy Production Summary\*

		Energy Production (kWh)				
		Site		By Turbine		
		P50 (Expected	Actual	L1	L2	L3
		Prodution)	Production	LI	LZ	Lo
	Aug-20	534,000	251,447	74,850	95,169	81,428
	Sep-20	736,000	700,759	241,924	248,089	210,746
	Oct-20	1,131,000	977,504	330,212	329,167	318,125
	Nov-20	1,281,000	1,381,160	464,646	463,381	453,133
	Dec-20	1,263,000	1,378,483	457,368	459,037	462,078
	Jan-21	1,433,000				
	Feb-21	1,213,000				
	Mar-21	1,339,000				
	Apr-21	1,327,000				
	May-21	1,052,000				
	Jun-21	751,000				
	Jul-21	609,000				
	Aug-21	534,000				
Production 2020 (ytd) (kWh)		4,945,000	4,689,353	1,569,000	1,594,843	1,525,510
Total Production (kWh)*		-	-	-	-	-
Capacity Factor*			-	*Value calculat	ed over the last 1	2 months

# **B. Site Energy Production Graph**





# Monthly Report December-2020



FINANCING WIND FOR INDUSTRY

# C. Safety Summary

	This Month	Project Cumulative	
Recordable Incident(s)	0	0	
Near Miss(es)	0	0	

#### **D. Planned Maintenance Events**

		Duration	
Date	Event	(hr)	Turbine
February-2021	Goldwind 6 Month Maintenance	~8	L1
February-2021	Goldwind 6 Month Maintenance	~8	L2
February-2021	Goldwind 6 Month Maintenance	~8	L3

## **E. Actual Maintenance Events**

		Planned/	Duration	
Date	Event	Unplanned	(hrs)	Turbine

# F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	99.97%	99.57%
L2	99.97%	99.63%
L3	100.00%	98.08%
Avg	99.98%	99.10%
Downtime (hr)	This Month	Year To Date
L1	3.91	40.98
L2	3.91	38.81
L3	3.70	80.54
Total	11.52	160.33

#### G. Billed Data

Meter Reading (Date/Time)	12/24/2020	12:00 AM
Meter To Date Produced	4,202,952	kWh
Meter To Date Consumed	13,494	kWh
Last Reading Produced	2,979,861	kWh
Last Reading Consumed	11,451	kWh
Billed kWh	1,221,048	kWh
Next Meter Reading	1/27/2021	12:00 AM

## H. Report Notes and Comments

<sup>\*</sup>Capacity factor to be included once full year of data is available.