




A. Site Energy Production Summary

	Energy Production (kWh)					
	Site		By Turbine			
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3	
Dec-19	1,217,000	1,216,234	461,480	437,079	317,675	*
Jan-20	1,343,000	966,360	362,196	344,267	259,897	*
Feb-20	1,133,000	849,494	298,415	266,192	284,887	
Mar-20	1,312,000	1,215,269	410,779	403,277	401,213	
Apr-20	1,272,000	1,065,044	362,884	353,029	349,131	
May-20	974,000	947,249	320,883	304,086	322,280	
Jun-20	714,000	616,108	211,039	201,746	203,323	
Jul-20	566,000	359,627	122,783	118,871	117,973	
Aug-20	514,000	352,591	121,092	114,292	117,207	
Sep-20	716,000	646,411	223,263	209,399	213,749	
Oct-20	1,051,000	889,528	302,399	297,007	290,122	
Nov-20	1,224,000	1,402,674	478,147	468,641	455,886	
Dec-20	1,217,000	1,248,705	447,838	423,268	377,599	
Production 2020 (ytd) (kWh)	12,036,000	10,559,060	3,661,718	3,504,075	3,393,267	
Total Production (kWh)*	12,036,000	10,559,060	3,661,718	3,504,075	3,393,267	
Capacity Factor*	26.71%		*Value calculated over the last 12 months			

B. Site Energy Production Graph

December-2020



Monthly Report
December-2020



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2021	Goldwind 2.5 Year Maintenance	~8	WG 1
April-2021	Goldwind 2.5 Year Maintenance	~8	WG 2
April-2021	Goldwind 2.5 Year Maintenance	~8	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
12/2-7/2020	Yaw Feedback Error	Unplanned	119.65	WG 3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WG1	100.00%	100.00%
WG2	99.98%	100.00%
WG3	99.47%	99.94%
Avg	99.82%	99.98%

Downtime (hr)	This Month	Year To Date
WG1	0.24	217.61
WG2	2.07	248.18
WG3	123.61	458.93
Total	125.92	924.72

G. Billed Data

Meter Reading (Date/Time)	12/29/2020 12:00 AM
Meter To Date Produced	22,999,749 kWh
Meter To Date Consumed	92,388 kWh
Last Reading Produced	21,802,942 kWh
Last Reading Consumed	90,334 kWh
Billed kWh	1,194,753 kWh
Next Meter Reading	1/29/2021 12:00 AM

H. Report Notes and Comments

*WG3 production for December 2019 and January 2020 is an estimate due to communication issue.