


### A. Site Energy Production Summary

|                             | Energy Production (kWh)   |                   |
|-----------------------------|---------------------------|-------------------|
|                             | Site                      |                   |
|                             | P50 (Expected Production) | Actual Production |
| Dec-19                      | 537,000                   | 480,035           |
| Jan-20                      | 455,000                   | 427,899           |
| Feb-20                      | 478,000                   | 353,172           |
| Mar-20                      | 422,000                   | 413,290           |
| Apr-20                      | 499,000                   | 397,381           |
| May-20                      | 318,000                   | 346,599           |
| Jun-20                      | 222,000                   | 262,997           |
| Jul-20                      | 201,000                   | 158,687           |
| Aug-20                      | 211,000                   | 159,430           |
| Sep-20                      | 182,000                   | 251,972           |
| Oct-20                      | 341,000                   | 341,043           |
| Nov-20                      | 445,000                   | 500,055           |
| Dec-20                      | 537,000                   | 478,426           |
| Production 2020 (ytd) (kWh) | 4,311,000                 | 4,090,951         |
| Total Production (kWh)*     | 4,311,000                 | 4,090,951         |
| Capacity Factor*            | 31.05%                    |                   |

\*Value calculated over the last 12 months

### B. Site Energy Production Graph

December-2020



## Monthly Report December-2020

### C. Safety Summary

|                        | This Month | Project Cumulative |
|------------------------|------------|--------------------|
| Recordable Incident(s) | 0          | 0                  |
| Near Miss(es)          | 0          | 0                  |

### D. Planned Maintenance Events

| Date       | Event                       | Duration (hr) | Turbine |
|------------|-----------------------------|---------------|---------|
| March-2021 | Goldwind 3 Year Maintenance | ~15           | W1      |

### E. Actual Maintenance Events

| Date        | Event          | Planned/Unplanned | Duration (hrs) | Turbine |
|-------------|----------------|-------------------|----------------|---------|
| 12/6-7/2020 | Profibus Error | Unplanned         | 15.91          | W1      |

### F. Turbine Availability & Downtime

| Availability | This Month | Year To Date |
|--------------|------------|--------------|
| W1           | 97.86%     | 99.64%       |

| Downtime (hr) | This Month | Year To Date |
|---------------|------------|--------------|
| W1            | 17.36      | 170.74       |

### G. Billed Data

|                           |                    |
|---------------------------|--------------------|
| Meter Reading (Date/Time) | 1/1/2021 12:00 AM  |
| Meter To Date Produced    | 11,356,275 kWh     |
| Meter To Date Consumed    | 54,669 kWh         |
| Last Reading Produced     | 10,884,300 kWh     |
| Last Reading Consumed     | 53,625 kWh         |
| <b>Billed kWh</b>         | <b>470,931 kWh</b> |
| Next Meter Reading        | 2/1/2021 12:00 AM  |

### H. Report Notes and Comments