


A. Site Energy Production Summary*

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Aug-20	534,000	251,447	74,850	95,169	81,428
Sep-20	736,000	700,759	241,924	248,089	210,746
Oct-20	1,131,000	977,504	330,212	329,167	318,125
Nov-20	1,281,000	1,381,160	464,646	463,381	453,133
Dec-20	1,263,000	1,378,483	457,368	459,037	462,078
Jan-21	1,433,000	897,220	303,778	298,866	294,576
Feb-21	1,213,000				
Mar-21	1,339,000				
Apr-21	1,327,000				
May-21	1,052,000				
Jun-21	751,000				
Jul-21	609,000				
Aug-21	534,000				
Production 2021 (ytd) (kWh)	1,433,000	897,220	303,778	298,866	294,576
Total Production (kWh)*	-	-	-	-	-
Capacity Factor*		-	*Value calculated over the last 12 months		

B. Site Energy Production Graph

January-2021



Monthly Report

January-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration	Turbine
		(hr)	
February-2021	Goldwind 6 Month Maintenance	~8	L1
February-2021	Goldwind 6 Month Maintenance	~8	L2
February-2021	Goldwind 6 Month Maintenance	~8	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration	Turbine
			(hrs)	
1/1-1/2/2021	Icing Stop	Unplanned	20.23	L1
1/1-1/2/2021	Icing Stop	Unplanned	20.36	L2
1/1-1/2/2021	Icing Stop	Unplanned	20.44	L3
1/4/2021	Blade Angle Error	Unplanned	6.97	L2
1/16/2021	Icing Stop	Unplanned	7.81	L3
1/22-1/23/2021	Plant Outage	Unplanned	25.58	L1
1/22-1/23/2021	Plant Outage	Unplanned	25.58	L2
1/22-1/23/2021	Plant Outage	Unplanned	25.58	L3
1/26-1/27/2021	Icing Stop	Unplanned	21.94	L1
1/26-1/28/2021	Icing Stop	Unplanned	39.84	L2
1/26/2021	Icing Stop	Unplanned	11.90	L3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	99.94%	99.94%
L2	98.99%	98.99%
L3	100.00%	100.00%
Avg	99.64%	99.64%

Downtime (hr)	This Month	Year To Date
L1	68.17	68.17
L2	93.33	93.33
L3	65.73	65.73
Total	227.23	227.23

G. Billed Data

Meter Reading (Date/Time)	1/27/2021 12:00 AM
Meter To Date Produced	5,353,206 kWh
Meter To Date Consumed	14,889 kWh
Last Reading Produced	4,202,952 kWh
Last Reading Consumed	13,494 kWh
Billed kWh	1,148,859 kWh
Next Meter Reading	2/25/2021 12:00 AM

H. Report Notes and Comments

*Capacity factor to be included once full year of data is available.