


A. Site Energy Production Summary*

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	V1	V2
Feb-20	736,000	640,848	302,976	337,872
Mar-20	794,000	758,754	383,099	375,655
Apr-20	734,000	726,579	367,253	359,326
May-20	574,000	632,754	315,995	316,759
Jun-20	429,000	501,469	246,974	254,495
Jul-20	357,000	314,450	154,487	159,963
Aug-20	303,000	306,534	150,783	155,751
Sep-20	431,000	462,340	229,259	233,081
Oct-20	674,000	557,016	279,004	278,012
Nov-20	796,000	913,861	455,668	458,193
Dec-20	820,000	810,783	417,721	393,062
Jan-21	931,000	544,556	269,433	275,123
Feb-21	737,000	766,729	389,871	376,858
Production 2021 (ytd) (kWh)	1,668,000	1,311,285	659,304	651,981
Total Production (kWh)*	7,580,000	7,295,825	3,659,547	3,636,278
Capacity Factor*	27.76%		*Value calculated over the last 12 months	

B. Site Energy Production Graph

February-2021



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-21	Goldwind 2.5 Year Maintenance	~8	V1
April-21	Goldwind 2.5 Year Maintenance	~8	V1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
V1	100.00%	99.99%
V2	99.97%	99.98%
Avg	99.98%	99.98%

Downtime (hr)	This Month	Year To Date
V1	3.50	35.04
V2	0.21	31.45
Total	3.71	66.49

G. Billed Data

Meter Reading (Date/Time)	3/1/2021 12:00 AM
Meter To Date Produced	17,931,159 kWh
Meter To Date Consumed	45,078 kWh
Last Reading Produced	17,181,630 kWh
Last Reading Consumed	44,119 kWh
Billed kWh	748,570 kWh
Next Meter Reading	4/1/2021 12:00 AM

H. Report Notes and Comments

*Change in production estimate due to Material Change of Circumstance.