


A. Site Energy Production Summary*

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Feb-20	908,000	670,274	317,389	352,885
Mar-20	803,000	795,295	400,369	394,926
Apr-20	949,000	706,174	357,900	348,274
May-20	603,000	633,162	322,304	310,858
Jun-20	422,000	512,907	257,351	255,556
Jul-20	383,000	317,320	159,723	157,597
Aug-20	399,000	300,935	157,115	143,820
Sep-20	337,000	489,578	244,573	245,005
Oct-20	637,000	603,877	306,458	297,419
Nov-20	834,000	945,207	479,511	465,696
Dec-20	1,015,000	887,367	445,540	441,827
Jan-21	875,000	568,442	288,651	279,791
Feb-21	917,000	760,836	386,235	374,601
Production 2021 (ytd) (kWh)	1,792,000	1,329,278	674,886	654,392
Total Production (kWh)*	8,174,000	7,521,100	3,805,730	3,715,370
Capacity Factor*	28.62%		*Value calculated over the last 12 months	

B. Site Energy Production Graph

February-2021



Monthly Report

February-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2021	Goldwind 5.5 Year Maintenance	~8	W1
April-2021	Goldwind 5.5 Year Maintenance	~8	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	100.00%
W2	99.96%	99.98%
Avg	99.98%	99.99%

Downtime (hr)	This Month	Year To Date
W1	0.00	35.55
W2	0.24	23.04
Total	0.24	58.59

H. Report Notes and Comments

*Change in production estimate due to Material Change of Circumstance.

G. Billed Data

Meter Reading (Date/Time)	03/01/2021 12:00 AM
Meter To Date Produced	39,518,692 kWh
Meter To Date Consumed	79,012 kWh
Last Reading Produced	38,691,919 kWh
Last Reading Consumed	78,039 kWh
Billed kWh	825,800 kWh
Next Meter Reading	3/29/2021 12:00 AM