



Holcim - Paulding Wind Project


Holcim - Paulding Wind Project, Paulding, Ohio

A. Site Energy Production Summary*

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Aug-20	534,000	251,447	74,850	95,169	81,428
Sep-20	736,000	700,759	241,924	248,089	210,746
Oct-20	1,131,000	977,504	330,212	329,167	318,125
Nov-20	1,281,000	1,381,160	464,646	463,381	453,133
Dec-20	1,263,000	1,378,483	457,368	459,037	462,078
Jan-21	1,433,000	897,220	303,778	298,866	294,576
Feb-21	1,213,000	1,067,166	373,080	349,858	344,228
Mar-21	1,339,000	1,506,920	494,282	505,088	507,550
Apr-21	1,327,000				
May-21	1,052,000				
Jun-21	751,000				
Jul-21	609,000				
Aug-21	534,000				
Production 2021 (ytd) (kWh)	3,985,000	3,471,306	1,171,140	1,153,812	1,146,354
Total Production (kWh)*	-	-	-	-	-
Capacity Factor*	- *Value calculated over the last 12 months				

B. Site Energy Production Graph

March-2021



Monthly Report

March-2021



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2021	Goldwind 1 Year Maintenance	~15	L1
September-2021	Goldwind 1 Year Maintenance	~15	L2
September-2021	Goldwind 1 Year Maintenance	~15	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
3/3/2021	Goldwind 6 Month Maintenance	Planned	3.25	L1
3/4/2021	Goldwind 6 Month Maintenance	Planned	3.00	L2
3/5/2021	Goldwind 6 Month Maintenance	Planned	2.47	L3
3/12/2021	Owner/Operator Maintenance	Unplanned	6.06	L1
3/12/2021	Owner/Operator Maintenance	Unplanned	6.06	L2
3/12/2021	Owner/Operator Maintenance	Unplanned	6.06	L3
3/25-26/2021	Weather Shutdown	Unplanned	7.42	L1
3/25-26/2021	Weather Shutdown	Unplanned	7.42	L2
3/25-26/2021	Weather Shutdown	Unplanned	7.42	L3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	100.00%	99.97%
L2	100.00%	99.39%
L3	100.00%	100.00%
Avg	100.00%	99.79%

Downtime (hr)	This Month	Year To Date
L1	16.73	90.06
L2	16.48	120.44
L3	15.95	114.74
Total	49.16	325.24

G. Billed Data

Meter Reading (Date/Time)	3/26/2021 12:00 AM
Meter To Date Produced	7,779,637 kWh
Meter To Date Consumed	21,557 kWh
Last Reading Produced	6,454,816 kWh
Last Reading Consumed	19,614 kWh
Billed kWh	1,322,878 kWh
Next Meter Reading	4/27/2021 12:00 AM

H. Report Notes and Comments

*Capacity factor to be included once full year of data is available.