


A. Site Energy Production Summary*

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Mar-20	803,000	795,295	400,369	394,926
Apr-20	949,000	706,174	357,900	348,274
May-20	603,000	633,162	322,304	310,858
Jun-20	422,000	512,907	257,351	255,556
Jul-20	383,000	317,320	159,723	157,597
Aug-20	399,000	300,935	157,115	143,820
Sep-20	337,000	489,578	244,573	245,005
Oct-20	637,000	603,877	306,458	297,419
Nov-20	834,000	945,207	479,511	465,696
Dec-20	1,015,000	887,367	445,540	441,827
Jan-21	875,000	568,442	288,651	279,791
Feb-21	917,000	760,836	386,235	374,601
Mar-21	802,000	962,627	490,998	471,629
Production 2021 (ytd) (kWh)	2,594,000	2,291,905	1,165,884	1,126,021
Total Production (kWh)*	8,173,000	7,688,432	3,896,359	3,792,073
Capacity Factor*	29.26%		*Value calculated over the last 12 months	

B. Site Energy Production Graph

March-2021



Monthly Report

March-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2021	Goldwind 5.5 Year Maintenance	~8	W1
April-2021	Goldwind 5.5 Year Maintenance	~8	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
3/25-26/2021	Weather Shutdown	Unplanned	7.43	W1, W2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	100.00%
W2	99.86%	99.94%
Avg	99.93%	99.97%

Downtime (hr)	This Month	Year To Date
W1	8.54	44.09
W2	9.60	32.64
Total	18.14	76.73

G. Billed Data

Meter Reading (Date/Time)	3/29/2021 12:00 AM
Meter To Date Produced	40,348,816 kWh
Meter To Date Consumed	79,931 kWh
Last Reading Produced	39,518,692 kWh
Last Reading Consumed	79,012 kWh
Billed kWh	829,205 kWh
Next Meter Reading	4/29/2021 12:00 AM

H. Report Notes and Comments

*Change in production estimate due to Material Change of Circumstance.