


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Apr-20	1,272,000	1,065,044	362,884	353,029	349,131
May-20	974,000	947,249	320,883	304,086	322,280
Jun-20	714,000	616,108	211,039	201,746	203,323
Jul-20	566,000	359,627	122,783	118,871	117,973
Aug-20	514,000	352,591	121,092	114,292	117,207
Sep-20	716,000	646,411	223,263	209,399	213,749
Oct-20	1,051,000	889,528	302,399	297,007	290,122
Nov-20	1,224,000	1,402,674	478,147	468,641	455,886
Dec-20	1,217,000	1,248,705	447,838	423,268	377,599
Jan-21	1,343,000	854,242	289,497	281,525	283,220
Feb-21	1,133,000	1,142,127	393,977	378,547	369,603
Mar-21	1,312,000	1,328,508	448,970	445,068	434,470
Apr-21	1,272,000	1,103,232	367,824	371,475	363,933
Production 2021 (ytd) (kWh)	5,060,000	4,428,109	1,500,268	1,476,615	1,451,226
Total Production (kWh)*	12,036,000	10,891,002	3,727,712	3,613,925	3,549,365
Capacity Factor*	27.63%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

April-2021



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2021	Goldwind 3 Year Maintenance	~15	WG 1
October-2021	Goldwind 3 Year Maintenance	~15	WG 2
October-2021	Goldwind 3 Year Maintenance	~15	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
4/20/2021	Owner/Operator Maintenance	Unplanned	5.17	WG 2
4/20/2021	Owner/Operator Maintenance	Unplanned	5.22	WG 3
4/20/2021	Owner/Operator Maintenance	Unplanned	4.25	WG 1
4/20/2021	Pitch System Error	Unplanned	10.53	WG 1
4/20/2021	Pitch System Error	Unplanned	8.00	WG 1
4/21/2021	Goldwind 2.5 Year Maintenance	Planned	4.32	WG 1
4/22/2021	Goldwind 2.5 Year Maintenance	Planned	3.14	WG 2
4/22/2021	Goldwind 2.5 Year Maintenance	Planned	4.17	WG 3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WG1	97.43%	99.02%
WG2	100.00%	100.00%
WG3	99.93%	99.46%
Avg	99.12%	99.49%

Downtime (hr)	This Month	Year To Date
WG1	27.10	80.85
WG2	8.31	51.56
WG3	9.92	69.45
Total	45.33	201.86

G. Billed Data

Meter Reading (Date/Time)	4/29/2021 12:00 AM
Meter To Date Produced	27,406,628 kWh
Meter To Date Consumed	101,995 kWh
Last Reading Produced	26,229,945 kWh
Last Reading Consumed	100,332 kWh
Billed kWh	1,175,020 kWh
Next Meter Reading	5/29/2021 12:00 AM

H. Report Notes and Comments