


A. Site Energy Production Summary*

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Aug-20	534,000	251,447	74,850	95,169	81,428
Sep-20	736,000	700,759	241,924	248,089	210,746
Oct-20	1,131,000	977,504	330,212	329,167	318,125
Nov-20	1,281,000	1,381,160	464,646	463,381	453,133
Dec-20	1,263,000	1,378,483	457,368	459,037	462,078
Jan-21	1,433,000	897,220	303,778	298,866	294,576
Feb-21	1,213,000	1,067,166	373,080	349,858	344,228
Mar-21	1,339,000	1,506,920	494,282	505,088	507,550
Apr-21	1,327,000	1,060,276	357,749	359,028	343,499
May-21	1,052,000	829,035	283,778	281,218	264,039
Jun-21	751,000	737,392	251,215	251,717	234,460
Jul-21	609,000				
Aug-21	534,000				
Production 2021 (ytd) (kWh)	7,115,000	6,098,009	2,063,882	2,045,775	1,988,352
Total Production (kWh)*	-	-	-	-	-
Capacity Factor*	- *Value calculated over the last 12 months				

B. Site Energy Production Graph

June-2021



Monthly Report

June-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2021	Goldwind 1 Year Maintenance	~15	L1
September-2021	Goldwind 1 Year Maintenance	~15	L2
September-2021	Goldwind 1 Year Maintenance	~15	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	100.00%	99.98%
L2	99.85%	99.67%
L3	100.00%	100.00%
Avg	99.95%	99.88%

Downtime (hr)	This Month	Year To Date
L1		95.94
L2	1.07	126.67
L3		118.93
Total	1.07	341.54

G. Billed Data

Meter Reading (Date/Time)	6/25/2021 12:00 AM
Meter To Date Produced	10,441,180 kWh
Meter To Date Consumed	31,421 kWh
Last Reading Produced	9,704,791 kWh
Last Reading Consumed	27,581 kWh
Billed kWh	732,549 kWh
Next Meter Reading	7/27/2021 12:00 AM

H. Report Notes and Comments

*Capacity factor to be included once full year of data is available.