


A. Site Energy Production Summary

		Energy Production (kWh)				
		Site		By Turbine		
		P50 (Expected Production)	Actual Production	W1	W2	W3
	Jun-20	634,000	542,111	193,735	179,058	169,318
	Jul-20	527,000	307,801	107,383	97,517	102,901
	Aug-20	449,000	319,596	107,014	102,774	109,808
	Sep-20	610,000	609,440	202,193	196,981	210,266
	Oct-20	990,000	736,506	247,147	240,678	248,681
	Nov-20	1,123,000	1,223,830	413,579	402,713	407,538
	Dec-20	1,153,000	857,603	285,868	285,868	285,868
	Jan-21	1,306,000	661,923	220,641	220,641	220,641
	Feb-21	1,137,000	896,420	308,413	291,691	296,316
	Mar-21	1,134,000	1,290,867	437,185	424,582	429,100
	Apr-21	1,176,000	752,920	257,397	246,019	249,504
	May-21	927,000	646,261	217,827	210,837	217,597
	Jun-21	634,000	571,998	186,211	188,627	197,160
Production 2021 (ytd) (kWh)		6,314,000	4,820,389	1,627,674	1,582,397	1,610,318
Total Production (kWh)*		11,166,000	8,875,166	2,990,858	2,908,928	2,975,380
Capacity Factor*		22.51% *Value calculated over the last 12 months				

B. Site Energy Production Graph

June-2021



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2021	Goldwind 4 Year Maintenance	~15	W1
October-2021	Goldwind 4 Year Maintenance	~15	W2
October-2021	Goldwind 4 Year Maintenance	~15	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
6/24/2021-6/25/2021	Curtailment Test/BOP Maintenance	Unplanned	23.41	W1
6/24/2021-6/25/2021	Curtailment Test/BOP Maintenance	Unplanned	23.41	W2
6/24/2021-6/25/2021	Curtailment Test/BOP Maintenance	Unplanned	26.67	W3

F. Turbine Availability & Downtime****

Availability	This Month	Year To Date
W1	100.00%	99.50%
W2	100.00%	99.92%
W3	100.00%	99.75%
Avg	100.00%	99.72%

Downtime (hr)	This Month	Year To Date
W1	27.05	236.12
W2	27.05	222.60
W3	30.31	232.27
Total	84.41	690.99

G. Billed Data

Meter Reading (Date/Time)	6/21/2021 12:00 AM
Meter To Date Produced	33,530,303 kWh
Meter To Date Consumed	99,872 kWh
Last Reading Produced	32,980,899 kWh
Last Reading Consumed	96,520 kWh
Billed kWh	546,052 kWh
Next Meter Reading	7/21/2021 12:00 AM

H. Report Notes and Comments

**December 2020 and January 2021 Production read from the meter due to communication issues and will be updated if SCADA data becomes available. Total metered production divided to estimate per turbine total.

***February 2021 Production is estimate due to communication issues.

****Year to date does not include January 2021 due to communication issue. April downtime and availability under further review.