



HARPSTER WIND PROJECT

Harpster, OH


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Jul-20	179,000	127,434
Aug-20	157,000	119,753
Sep-20	224,000	194,360
Oct-20	338,000	240,522
Nov-20	402,000	356,013
Dec-20	403,000	399,725
Jan-21	460,000	252,077
Feb-21	372,000	359,816
Mar-21	417,000	441,144
Apr-21	399,000	331,073
May-21	311,000	211,014
Jun-21	228,000	199,146
Jul-21	179,000	117,480
Production 2021 (ytd) (kWh)	2,366,000	1,911,750
Total Production (kWh)*	3,890,000	3,222,123
Capacity Factor*	24.52%	

*Value calculated over the last 12 months

B. Site Energy Production Graph

July-2021



Monthly Report

July-2021



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2021	Goldwind 5.5 Year Maintenance	~8	H1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
7/11/2021	Grid Fault	Unplanned	5.26	H1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
H1	99.91%	99.97%
Downtime (hr)	This Month	Year To Date
H1	10.43	54.33

G. Billed Data

Meter Reading (Date/Time)	7/27/2021 12:00 AM
Meter To Date Produced	17,917,155 kWh
Meter To Date Consumed	60,732 kWh
Last Reading Produced	17,764,566 kWh
Last Reading Consumed	59,421 kWh
Billed kWh	151,278 kWh
Next Meter Reading	8/25/2021 12:00 AM

H. Report Notes and Comments