


A. Site Energy Production Summary*

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Jul-20	383,000	317,320	159,723	157,597
Aug-20	399,000	300,935	157,115	143,820
Sep-20	337,000	489,578	244,573	245,005
Oct-20	637,000	603,877	306,458	297,419
Nov-20	834,000	945,207	479,511	465,696
Dec-20	1,015,000	887,367	445,540	441,827
Jan-21	875,000	568,442	288,651	279,791
Feb-21	917,000	760,836	386,235	374,601
Mar-21	802,000	962,627	490,998	471,629
Apr-21	951,000	667,905	338,467	329,438
May-21	601,000	509,680	262,275	247,405
Jun-21	425,000	479,735	244,261	235,474
Jul-21	390,000	298,836	152,425	146,411
Production 2021 (ytd) (kWh)	4,961,000	4,248,061	2,163,312	2,084,749
Total Production (kWh)*	8,183,000	7,475,025	3,796,509	3,678,516
Capacity Factor*	28.44%		*Value calculated over the last 12 months	

B. Site Energy Production Graph

July-2021



Monthly Report July-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2021	Goldwind 6 Year Maintenance	~15	W1
October-2021	Goldwind 6 Year Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.75%
W2	100.00%	99.72%
Avg	100.00%	99.74%

Downtime (hr)	This Month	Year To Date
W1	6.58	79.30
W2	0.68	71.34
Total	7.26	150.64

H. Report Notes and Comments

*Change in production estimate due to Material Change of Circumstance.

G. Billed Data

Meter Reading (Date/Time)	07/29/2021 12:00 AM
Meter To Date Produced	42,363,339 kWh
Meter To Date Consumed	85,083 kWh
Last Reading Produced	42,087,033 kWh
Last Reading Consumed	83,448 kWh
Billed kWh	274,671 kWh
Next Meter Reading	8/29/2021 12:00 AM