


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Aug-20	399,000	300,935	157,115	143,820
Sep-20	337,000	489,578	244,573	245,005
Oct-20	637,000	603,877	306,458	297,419
Nov-20	834,000	945,207	479,511	465,696
Dec-20	1,015,000	887,367	445,540	441,827
Jan-21	875,000	568,442	288,651	279,791
Feb-21	917,000	760,836	386,235	374,601
Mar-21	802,000	962,627	490,998	471,629
Apr-21	951,000	667,905	338,467	329,438
May-21	601,000	509,680	262,275	247,405
Jun-21	425,000	479,735	244,261	235,474
Jul-21	390,000	298,836	152,425	146,411
Aug-21	399,000	297,535	152,628	144,907
Production 2021 (ytd) (kWh)	5,360,000	4,545,596	2,315,940	2,229,656
Total Production (kWh)*	8,183,000	7,471,625	3,792,022	3,679,603
Capacity Factor*	28.43%		*Value calculated over the last 12 months	

B. Site Energy Production Graph

August-2021



Monthly Report

August-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2021	Goldwind 6 Year Maintenance	~15	W1
October-2021	Goldwind 6 Year Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.78%
W2	99.98%	99.75%
Avg	99.99%	99.77%

Downtime (hr)	This Month	Year To Date
W1	1.52	80.82
W2	1.62	72.96
Total	3.14	153.78

G. Billed Data

Meter Reading (Date/Time)	08/29/2021 12:00 AM
Meter To Date Produced	42,652,553 kWh
Meter To Date Consumed	87,244 kWh
Last Reading Produced	42,363,339 kWh
Last Reading Consumed	85,083 kWh
Billed kWh	287,053 kWh
Next Meter Reading	9/29/2021 12:00 AM

H. Report Notes and Comments