


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Aug-20	514,000	352,591	121,092	114,292	117,207
Sep-20	716,000	646,411	223,263	209,399	213,749
Oct-20	1,051,000	889,528	302,399	297,007	290,122
Nov-20	1,224,000	1,402,674	478,147	468,641	455,886
Dec-20	1,217,000	1,248,705	447,838	423,268	377,599
Jan-21	1,343,000	854,242	289,497	281,525	283,220
Feb-21	1,133,000	1,142,127	393,977	378,547	369,603
Mar-21	1,312,000	1,328,508	448,970	445,068	434,470
Apr-21	1,272,000	1,103,232	367,824	371,475	363,933
May-21	974,000	741,489	252,278	248,726	240,485
Jun-21	714,000	707,606	237,423	237,814	232,369
Jul-21	566,000	393,393	134,849	129,596	128,948
Aug-21	514,000	411,193	140,054	135,185	135,954
Production 2021 (ytd) (kWh)	7,828,000	6,681,790	2,264,872	2,227,936	2,188,982
Total Production (kWh)*	12,036,000	10,869,108	3,716,519	3,626,251	3,526,338
Capacity Factor*	27.57%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

August-2021



Monthly Report August-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2021	Goldwind 3 Year Maintenance	~15	WG 1
October-2021	Goldwind 3 Year Maintenance	~15	WG 2
October-2021	Goldwind 3 Year Maintenance	~15	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
8/6/2021	Blade Inspection	Planned	1.55	WG 1
8/6/2021	Blade Inspection	Planned	1.98	WG 2
8/6/2021	Blade Inspection	Planned	1.50	WG 3
8/18/2021-8/19/2021	Turbine Fault	Unplanned	13.97	WG 1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WG1	98.12%	99.00%
WG2	100.00%	100.00%
WG3	100.00%	99.36%
Avg	99.37%	99.46%

Downtime (hr)	This Month	Year To Date
WG1	16.74	119.10
WG2	3.20	59.51
WG3	2.71	98.90
Total	22.65	277.51

G. Billed Data

Meter Reading (Date/Time)	8/29/2021 12:00 AM
Meter To Date Produced	29,688,677 kWh
Meter To Date Consumed	120,156 kWh
Last Reading Produced	29,282,558 kWh
Last Reading Consumed	114,164 kWh
Billed kWh	400,127 kWh
Next Meter Reading	9/29/2021 12:00 AM

H. Report Notes and Comments