




A. Site Energy Production Summary

	Energy Production (kWh)					
	Site		By Turbine			
	Expected Production	Actual Production	WTG A	WTG B	WTG C	
Sep-20	631,697	783,680	265,500	264,220	253,960	
Oct-20	1,003,602	1,025,730	341,910	341,910	341,910	**
Nov-20	1,395,914	1,546,320	515,440	515,440	515,440	**
Dec-20	1,278,858	1,465,048	488,349	488,349	488,349	**
Jan-21	1,332,437	995,915	331,972	331,972	331,972	**
Feb-21	1,157,019	1,160,396	386,799	386,799	386,799	**
Mar-21	1,242,761	1,601,636	533,879	533,879	533,879	**
Apr-21	1,447,248	1,114,956	371,652	371,652	371,652	**
May-21	1,010,966	876,324	292,108	292,108	292,108	**
Jun-21	668,411	811,402	270,467	270,467	270,467	**
Jul-21	638,097	457,358	152,453	152,453	152,453	**
Aug-21	577,992	450,170	150,057	150,057	150,057	**
Sep-21	631,697	1,046,539	348,846	348,846	348,846	**
Production 2021 (ytd) (kWh)	8,706,626	8,514,697	2,838,232	2,838,232	2,838,232	
Total Production (kWh)*	12,384,999	12,551,793	4,183,931	4,183,931	4,183,931	
Capacity Factor*	31.84%		*Value calculated over the last 12 months			

B. Site Energy Production Graph

September-2021



Monthly Report September-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*****

Date	Event	Duration (hr)	Turbine
October-2021	Goldwind 9 Year Maintenance	~15	WTG A
October-2021	Goldwind 9 Year Maintenance	~15	WTG B
October-2021	Goldwind 9 Year Maintenance	~15	WTG C

E. Actual Maintenance Events***

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime***

Availability	This Month	Year To Date
WTG A		
WTG B		
WTG C		
Avg		

Downtime (hr)	This Month	Year To Date
WTG A		
WTG B		
WTG C		
Total		

G. Wind Speed & Capacity Factor****

Wind Speed (mph)	This Month	2021 Annual
WTG A		
WTG B		
WTG C		
Estimated	11.09	13.39

Capacity Factor (%)	This Month	2021 Annual
WTG A	32.30%	
WTG B	32.30%	
WTG C	32.30%	
Low Estimate	18.42%	28.72%

H. Report Notes and Comments

**Production read from the meter due to communication issues and will be updated if SCADA data becomes available. Total metered production divided to estimate per turbine total.

***Downtime and Availability pending data availability. One Energy Maintenance duration to be updated pending data availability.

****Wind speed pending data availability. Capacity factors estimated based on metered production.

*****Goldwind 9 Year Maintenance moved to October.