


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Sep-20	716,000	646,411	223,263	209,399	213,749
Oct-20	1,051,000	889,528	302,399	297,007	290,122
Nov-20	1,224,000	1,402,674	478,147	468,641	455,886
Dec-20	1,217,000	1,248,705	447,838	423,268	377,599
Jan-21	1,343,000	854,242	289,497	281,525	283,220
Feb-21	1,133,000	1,142,127	393,977	378,547	369,603
Mar-21	1,312,000	1,328,508	448,970	445,068	434,470
Apr-21	1,272,000	1,103,232	367,824	371,475	363,933
May-21	974,000	741,489	252,278	248,726	240,485
Jun-21	714,000	707,606	237,423	237,814	232,369
Jul-21	566,000	393,393	134,849	129,596	128,948
Aug-21	514,000	411,193	140,054	135,185	135,954
Sep-21	716,000	957,296	328,228	316,256	312,812
Production 2021 (ytd) (kWh)	8,544,000	7,639,086	2,593,100	2,544,192	2,501,794
Total Production (kWh)*	12,036,000	11,179,993	3,821,484	3,733,108	3,625,401
Capacity Factor*	28.36%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

September-2021



Monthly Report September-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2021	Goldwind 3 Year Maintenance	~15	WG 1
October-2021	Goldwind 3 Year Maintenance	~15	WG 2
October-2021	Goldwind 3 Year Maintenance	~15	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
9/10/2021	One Energy Annual Inspection	Unplanned	2.17	W1
9/10/2021	One Energy Annual Inspection	Unplanned	4.33	WG 2, WG 3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WG1	99.73%	99.08%
WG2	100.00%	100.00%
WG3	100.00%	99.43%
Avg	99.91%	99.51%

Downtime (hr)	This Month	Year To Date
WG1	4.11	123.21
WG2	4.33	63.84
WG3	4.33	103.23
Total	12.77	290.28

G. Billed Data

Meter Reading (Date/Time)	9/29/2021 12:00 AM
Meter To Date Produced	30,661,940 kWh
Meter To Date Consumed	123,112 kWh
Last Reading Produced	29,688,677 kWh
Last Reading Consumed	120,156 kWh
Billed kWh	970,307 kWh
Next Meter Reading	10/29/2021 12:00 AM

H. Report Notes and Comments