


A. Site Energy Production Summary

		Energy Production (kWh)					
		Site		By Turbine			
		P50 (Expected Production)	Actual Production	W1	W2		W3
	Sep-20	610,000	609,440	202,193	196,981	210,266	
	Oct-20	990,000	736,506	247,147	240,678	248,681	
	Nov-20	1,123,000	1,223,830	413,579	402,713	407,538	
	Dec-20	1,153,000	857,603	285,868	285,868	285,868	**
	Jan-21	1,306,000	661,923	220,641	220,641	220,641	**
	Feb-21	1,137,000	896,420	308,413	291,691	296,316	***
	Mar-21	1,134,000	1,290,867	437,185	424,582	429,100	
	Apr-21	1,176,000	752,920	257,397	246,019	249,504	
	May-21	927,000	646,261	217,827	210,837	217,597	
	Jun-21	634,000	571,998	186,211	188,627	197,160	
	Jul-21	527,000	318,063	107,885	100,155	110,023	
	Aug-21	449,000	324,019	109,256	105,233	109,530	
	Sep-21	610,000	740,131	243,253	241,498	255,380	
Production 2021 (ytd) (kWh)		7,900,000	6,202,602	2,088,068	2,029,283	2,085,251	
Total Production (kWh)*		11,166,000	9,020,542	3,034,662	2,958,542	3,027,338	
Capacity Factor*		22.88%		*Value calculated over the last 12 months			

B. Site Energy Production Graph

September-2021



Monthly Report September-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2021	Goldwind 4 Year Maintenance	~15	W1
October-2021	Goldwind 4 Year Maintenance	~15	W2
October-2021	Goldwind 4 Year Maintenance	~15	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
9/28/2021	One Energy Annual Inspection	Unplanned	5.12	W1
9/28/2021	One Energy Annual Inspection	Unplanned	6.09	W2
9/28/2021	One Energy Annual Inspection	Unplanned	6.08	W3

F. Turbine Availability & Downtime****

Availability	This Month	Year To Date
W1	99.48%	99.62%
W2	100.00%	99.95%
W3	99.31%	99.69%
Avg	99.60%	99.75%

Downtime (hr)	This Month	Year To Date
W1	8.83	253.06
W2	6.09	240.26
W3	11.05	256.38
Total	25.97	749.70

G. Billed Data

Meter Reading (Date/Time)	9/21/2021 12:00 AM
Meter To Date Produced	34,816,028 kWh
Meter To Date Consumed	110,702 kWh
Last Reading Produced	34,376,730 kWh
Last Reading Consumed	106,662 kWh
Billed kWh	435,258 kWh
Next Meter Reading	10/21/2021 12:00 AM

H. Report Notes and Comments

**December 2020 and January 2021 Production read from the meter due to communication issues and will be updated if SCADA data becomes available. Total metered production divided to estimate per turbine total.

***February 2021 Production is estimate due to communication issues.

****Year to date does not include January 2021 due to communication issue. April downtime and availability under further review.