


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Sep-20	182,000	251,972
Oct-20	341,000	341,043
Nov-20	445,000	500,055
Dec-20	537,000	478,426
Jan-21	455,000	312,598
Feb-21	478,000	404,742
Mar-21	422,000	513,464
Apr-21	499,000	370,891
May-21	318,000	262,656
Jun-21	222,000	267,226
Jul-21	201,000	157,870
Aug-21	211,000	138,271
Sep-21	182,000	352,762
Production 2021 (ytd) (kWh)	2,988,000	2,780,480
Total Production (kWh)*	4,311,000	4,100,004
Capacity Factor*	31.20%	

*Value calculated over the last 12 months

B. Site Energy Production Graph

September-2021



Monthly Report
September-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2021	Goldwind 3.5 Year Maintenance	~8	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
9/30/2021	One Energy Annual Inspection	Unplanned	2.82	W1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.95%
Downtime (hr)	This Month	Year To Date
W1	3.49	62.81

G. Billed Data

Meter Reading (Date/Time)	10/1/2021 12:00 AM
Meter To Date Produced	14,096,181 kWh
Meter To Date Consumed	67,159 kWh
Last Reading Produced	13,748,164 kWh
Last Reading Consumed	65,967 kWh
Billed kWh	346,825 kWh
Next Meter Reading	11/1/2021 12:00 AM

H. Report Notes and Comments