


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	Z4	Z5	Z6
Oct-20	956,000	850,601	284,918	272,587	293,096
Nov-20	1,107,000	1,330,282	442,746	426,184	461,352
Dec-20	1,098,000	1,263,339	421,761	411,065	430,513
Jan-21	1,251,000	798,530	263,091	267,336	268,103
Feb-21	1,044,000	1,137,529	368,454	371,784	397,291
Mar-21	1,119,000	1,351,254	441,435	433,777	476,042
Apr-21	1,116,000	941,559	301,517	305,193	334,849
May-21	876,000	755,823	246,357	249,062	260,404
Jun-21	637,000	667,180	226,175	213,521	227,484
Jul-21	518,000	423,089	144,295	141,912	136,882
Aug-21	448,000	407,609	139,023	132,947	135,639
Sep-21	617,000	957,074	321,730	316,478	318,866
Oct-21	956,000	739,181	243,855	238,641	256,685
Production 2021 (ytd) (kWh)	8,582,000	8,178,828	2,695,932	2,670,651	2,812,245
Total Production (kWh)*	10,787,000	10,772,449	3,560,439	3,507,900	3,704,110
Capacity Factor*	27.33%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

October-2021



Monthly Report

October-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
March-2022	Goldwind 1.5 Year Maintenance	~8	Z4
March-2022	Goldwind 1.5 Year Maintenance	~8	Z5
March-2022	Goldwind 1.5 Year Maintenance	~8	Z6

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
10/1/2021	Turbine Fault	Unplanned	5.17	Z5
10/6/2021	One Energy Annual Inspection	Planned	2.59	Z4
10/6/2021	One Energy Annual Inspection	Planned	2.85	Z5
10/6/2021	One Energy Annual Inspection	Planned	2.96	Z6
10/19/2021	Goldwind 1 Year Maintenance	Planned	3.24	Z4
10/19/2021	Goldwind 1 Year Maintenance	Planned	3.24	Z5
10/19/2021	Goldwind 1 Year Maintenance	Planned	3.24	Z6

F. Turbine Availability & Downtime*

Availability	This Month	Year To Date
Z4	100.00%	99.91%
Z5	99.31%	99.86%
Z6	100.00%	99.62%
Avg	99.77%	99.79%

Downtime (hr)	This Month	Year To Date
Z4	6.49	108.44
Z5	11.92	80.66
Z6	6.86	108.72
Total	25.27	297.82

H. Report Notes and Comments

*March downtime and availability under further review.

G. Billed Data

Meter Reading (Date/Time)	10/16/2021 12:00 AM
Ball 2.0 Production (This Period)	779,689 kWh
Ball 2.0 Consumption (This Period)	2,026 kWh
Billed kWh	777,663 kWh
Next Meter Reading	11/16/2021 12:00 AM