



HARPSTER WIND PROJECT

Harpster, OH


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Oct-20	338,000	240,522
Nov-20	402,000	356,013
Dec-20	403,000	399,725
Jan-21	460,000	252,077
Feb-21	372,000	359,816
Mar-21	417,000	441,144
Apr-21	399,000	331,073
May-21	311,000	211,014
Jun-21	228,000	199,146
Jul-21	179,000	117,480
Aug-21	157,000	116,887
Sep-21	224,000	257,547
Oct-21	338,000	223,963
Production 2021 (ytd) (kWh)	3,085,000	2,510,147
Total Production (kWh)*	3,890,000	3,265,885
Capacity Factor*	24.85%	

*Value calculated over the last 12 months

B. Site Energy Production Graph

October-2021



Monthly Report October-2021



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2022	Goldwind 6 Year Maintenance	~15	H1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
10/20/2021-10/22/2021	Turbine Fault	Unplanned	29.95	H1
10/28/2021	Goldwind 5.5 Year Maintenance	Planned	5.53	H1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
H1	95.97%	99.56%
Downtime (hr)	This Month	Year To Date
H1	35.25	100.52

G. Billed Data

Meter Reading (Date/Time)	10/23/2021 12:00 AM
Meter To Date Produced	18,459,754 kWh
Meter To Date Consumed	63,980 kWh
Last Reading Produced	18,234,100 kWh
Last Reading Consumed	63,314 kWh
Billed kWh	224,988 kWh
Next Meter Reading	11/23/2021 12:00 AM

H. Report Notes and Comments