


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Oct-20	1,131,000	977,504	330,212	329,167	318,125
Nov-20	1,281,000	1,381,160	464,646	463,381	453,133
Dec-20	1,263,000	1,378,483	457,368	459,037	462,078
Jan-21	1,433,000	897,220	303,778	298,866	294,576
Feb-21	1,213,000	1,067,166	373,080	349,858	344,228
Mar-21	1,339,000	1,506,920	494,282	505,088	507,550
Apr-21	1,327,000	1,060,276	357,749	359,028	343,499
May-21	1,052,000	829,035	283,778	281,218	264,039
Jun-21	751,000	737,392	251,215	251,717	234,460
Jul-21	609,000	494,693	174,014	172,212	148,467
Aug-21	534,000	418,734	143,423	142,983	132,328
Sep-21	736,000	984,373	335,478	342,450	306,445
Oct-21	1,131,000	871,887	297,865	295,436	278,586
Production 2021 (ytd) (kWh)	10,125,000	8,867,696	3,014,662	2,998,856	2,854,178
Total Production (kWh)*	12,669,000	11,627,339	3,936,676	3,921,274	3,769,389
Capacity Factor*	29.50%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

October-2021



Monthly Report
October-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
March-2022	Goldwind 1.5 Year Maintenance	~8	L1
March-2022	Goldwind 1.5 Year Maintenance	~8	L2
March-2022	Goldwind 1.5 Year Maintenance	~8	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
10/1/2021	One Energy Annual Inspection	Planned	3.83	L1
10/1/2021	One Energy Annual Inspection	Planned	4.67	L2
10/1/2021	One Energy Annual Inspection	Planned	4.33	L3
10/27/2021	Turbine Fault	Unplanned	12.66	L3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	100.00%	99.95%
L2	99.92%	99.78%
L3	98.30%	99.83%
Avg	99.40%	99.85%

Downtime (hr)	This Month	Year To Date
L1	3.83	123.96
L2	5.30	150.37
L3	16.99	152.98
Total	26.12	427.31

G. Billed Data

Meter Reading (Date/Time)	10/23/2021 12:00 AM
Meter To Date Produced	13,143,291 kWh
Meter To Date Consumed	47,946 kWh
Last Reading Produced	12,290,695 kWh
Last Reading Consumed	45,272 kWh
Billed kWh	849,922 kWh
Next Meter Reading	11/23/2021 12:00 AM

H. Report Notes and Comments