


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Nov-20	834,000	945,207	479,511	465,696
Dec-20	1,015,000	887,367	445,540	441,827
Jan-21	875,000	568,442	288,651	279,791
Feb-21	917,000	760,836	386,235	374,601
Mar-21	802,000	962,627	490,998	471,629
Apr-21	951,000	667,905	338,467	329,438
May-21	601,000	509,680	262,275	247,405
Jun-21	425,000	479,735	244,261	235,474
Jul-21	390,000	298,836	152,425	146,411
Aug-21	399,000	297,535	152,628	144,907
Sep-21	337,000	665,033	337,170	327,863
Oct-21	637,000	518,984	262,835	256,149
Nov-21	834,000	849,882	425,765	424,117
Production 2021 (ytd) (kWh)	7,168,000	6,579,495	3,341,710	3,237,785
Total Production (kWh) (LTM)	8,183,000	7,466,862	3,787,250	3,679,612
Capacity Factor (LTM)	28.41%			

B. Site Energy Production Graph

November-2021



Monthly Report

November-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2022	Goldwind 6.5 Year Maintenance	~8	W1
May-2022	Goldwind 6.5 Year Maintenance	~8	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
11/3/2021	Goldwind 6 Year Maintenance	Planned	3.28	W1
11/3/2021	Goldwind 6 Year Maintenance	Planned	3.34	W2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.84%
W2	100.00%	99.81%
Avg	100.00%	99.83%

Downtime (hr)	This Month	Year To Date
W1	3.28	90.95
W2	4.09	84.16
Total	7.37	175.11

G. Billed Data

Meter Reading (Date/Time)	11/29/2021 12:00 AM
Meter To Date Produced	44,658,011 kWh
Meter To Date Consumed	90,147 kWh
Last Reading Produced	43,804,915 kWh
Last Reading Consumed	89,316 kWh
Billed kWh	852,265 kWh
Next Meter Reading	12/29/2021 12:00 AM

H. Report Notes and Comments