


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Nov-20	1,224,000	1,402,674	478,147	468,641	455,886
Dec-20	1,217,000	1,248,705	447,838	423,268	377,599
Jan-21	1,343,000	854,242	289,497	281,525	283,220
Feb-21	1,133,000	1,142,127	393,977	378,547	369,603
Mar-21	1,312,000	1,328,508	448,970	445,068	434,470
Apr-21	1,272,000	1,103,232	367,824	371,475	363,933
May-21	974,000	741,489	252,278	248,726	240,485
Jun-21	714,000	707,606	237,423	237,814	232,369
Jul-21	566,000	393,393	134,849	129,596	128,948
Aug-21	514,000	411,193	140,054	135,185	135,954
Sep-21	716,000	957,296	328,228	316,256	312,812
Oct-21	1,051,000	805,356	280,398	266,167	258,791
Nov-21	1,224,000	1,149,191	399,017	380,196	369,978
Production 2021 (ytd) (kWh)	10,819,000	9,593,633	3,272,515	3,190,555	3,130,563
Total Production (kWh)*	12,036,000	10,842,338	3,720,353	3,613,823	3,508,162
Capacity Factor*	27.50%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

November-2021



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2022	Goldwind 3.5 Year Maintenance	~8	WG 1
May-2022	Goldwind 3.5 Year Maintenance	~8	WG 2
May-2022	Goldwind 3.5 Year Maintenance	~8	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
11/8/2021-11/9/2021	Goldwind 3 Year Maintenance	Planned	7.51	W1
11/9/2021	Goldwind 3 Year Maintenance	Planned	5.30	W2
11/9/2021-11/10/2021	Goldwind 3 Year Maintenance	Planned	5.57	W3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WG1	100.00%	99.24%
WG2	100.00%	100.00%
WG3	100.00%	99.54%
Avg	100.00%	99.59%

Downtime (hr)	This Month	Year To Date
WG1	7.51	134.07
WG2	5.30	71.81
WG3	5.57	111.46
Total	18.38	317.34

G. Billed Data

Meter Reading (Date/Time)	11/29/2021 12:00 AM
Meter To Date Produced	32,539,897 kWh
Meter To Date Consumed	128,733 kWh
Last Reading Produced	31,397,698 kWh
Last Reading Consumed	126,370 kWh
Billed kWh	1,139,836 kWh
Next Meter Reading	12/29/2021 12:00 AM

H. Report Notes and Comments