


A. Site Energy Production Summary

	Energy Production (kWh)					
	Site		By Turbine			
	P50 (Expected Production)	Actual Production	W1	W2	W3	
Nov-20	1,123,000	1,223,830	413,579	402,713	407,538	
Dec-20	1,153,000	857,603	285,868	285,868	285,868	**
Jan-21	1,306,000	661,923	220,641	220,641	220,641	**
Feb-21	1,137,000	896,420	308,413	291,691	296,316	***
Mar-21	1,134,000	1,290,867	437,185	424,582	429,100	
Apr-21	1,176,000	752,920	257,397	246,019	249,504	
May-21	927,000	646,261	217,827	210,837	217,597	
Jun-21	634,000	571,998	186,211	188,627	197,160	
Jul-21	527,000	318,063	107,885	100,155	110,023	
Aug-21	449,000	324,019	109,256	105,233	109,530	
Sep-21	610,000	740,131	243,253	241,498	255,380	
Oct-21	990,000	693,360	241,616	219,829	231,915	
Nov-21	1,123,000	976,482	349,225	311,053	316,204	
Production 2021 (ytd) (kWh)	10,013,000	7,872,444	2,678,909	2,560,165	2,633,370	
Total Production (kWh) (LTM)	11,166,000	8,730,048	2,964,777	2,846,033	2,919,238	
Capacity Factor (LTM)	22.15%					

B. Site Energy Production Graph

November-2021



Monthly Report
November-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2022	Goldwind 4.5 Year Maintenance	~8	W1
May-2022	Goldwind 4.5 Year Maintenance	~8	W2
May-2022	Goldwind 4.5 Year Maintenance	~8	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
11/1/2021-11/2/2021	Goldwind 4 Year Maintenance	Planned	4.86	W1
11/1/2021-11/2/2021	Goldwind 4 Year Maintenance	Planned	4.07	W2
11/2/2021	Goldwind 4 Year Maintenance	Planned	4.38	W3

F. Turbine Availability & Downtime****

Availability	This Month	Year To Date
W1	100.00%	99.70%
W2	100.00%	99.96%
W3	100.00%	99.75%
Avg	100.00%	99.80%

Downtime (hr)	This Month	Year To Date
W1	4.86	257.92
W2	4.07	244.33
W3	4.38	260.76
Total	13.31	763.01

G. Billed Data

Meter Reading (Date/Time)	11/21/2021 12:00 AM
Meter To Date Produced	36,396,118 kWh
Meter To Date Consumed	114,673 kWh
Last Reading Produced	35,562,410 kWh
Last Reading Consumed	112,262 kWh
Billed kWh	831,297 kWh
Next Meter Reading	12/21/2021 12:00 AM

H. Report Notes and Comments

**December 2020 and January 2021 Production read from the meter due to communication issues and will be updated if SCADA data becomes available. Total metered production divided to estimate per turbine total.

***February 2021 Production is estimate due to communication issues.

****Year to date does not include January 2021 due to communication issue. April downtime and availability under further review.