


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Dec-20	1,263,000	1,378,483	457,368	459,037	462,078
Jan-21	1,433,000	897,220	303,778	298,866	294,576
Feb-21	1,213,000	1,067,166	373,080	349,858	344,228
Mar-21	1,339,000	1,506,920	494,282	505,088	507,550
Apr-21	1,327,000	1,060,276	357,749	359,028	343,499
May-21	1,052,000	829,035	283,778	281,218	264,039
Jun-21	751,000	737,392	251,215	251,717	234,460
Jul-21	609,000	494,693	174,014	172,212	148,467
Aug-21	534,000	418,734	143,423	142,983	132,328
Sep-21	736,000	984,373	335,478	342,450	306,445
Oct-21	1,131,000	871,887	297,865	295,436	278,586
Nov-21	1,281,000	1,196,514	350,141	425,981	420,392
Dec-21	1,263,000	1,233,907	413,245	410,712	409,950
Production 2021 (ytd) (kWh)	12,669,000	11,298,117	3,778,048	3,835,549	3,684,520
Total Production (kWh)*	12,669,000	11,298,117	3,778,048	3,835,549	3,684,520
Capacity Factor*	28.66%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

December-2021



Monthly Report
December-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
March-2022	Goldwind 1.5 Year Maintenance	~8	L1
March-2022	Goldwind 1.5 Year Maintenance	~8	L2
March-2022	Goldwind 1.5 Year Maintenance	~8	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
12/11/2021	Turbine Fault	Unplanned	8.17	L2
12/11/2021	Turbine Fault	Unplanned	8.11	L3
12/24/2021	Grid Fault	Unplanned	7.83	L1, L2, L3
12/28 - 29/2021	Weather Shutdown	Unplanned	10.20	L1, L2, L3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	100.00%	99.96%
L2	98.85%	99.72%
L3	98.88%	99.76%
Avg	99.24%	99.81%

Downtime (hr)	This Month	Year To Date
L1	19.06	267.75
L2	27.62	178.36
L3	27.46	180.44
Total	74.14	626.55

G. Billed Data

Meter Reading (Date/Time)	12/28/2021 12:00 AM
Meter To Date Produced	15,770,244 kWh
Meter To Date Consumed	53,130 kWh
Last Reading Produced	14,346,367 kWh
Last Reading Consumed	50,241 kWh
Billed kWh	1,420,988 kWh
Next Meter Reading	1/27/2022 12:00 AM

H. Report Notes and Comments

*December 2021 Downtime and Availability numbers are pending review and will be confirmed in the January 2022 report.