



BALL CORPORATION - ZEPHYR WIND PROJECT 1.0

North Findlay Wind Campus, Findlay, OH

Monthly Report December-2021




A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	Z1	Z2	Z3
Dec-20	1,475,000	1,298,566	447,593	437,476	413,497
Jan-21	1,260,000	763,428	269,281	243,111	251,036
Feb-21	1,310,000	1,112,551	384,385	376,283	351,883
Mar-21	1,140,000	1,328,761	439,843	458,260	430,658
Apr-21	1,359,000	930,702	327,011	316,411	287,280
May-21	856,000	723,486	251,234	238,571	233,681
Jun-21	599,000	668,103	237,234	223,304	207,565
Jul-21	549,000	406,084	144,149	134,124	127,811
Aug-21	559,000	401,761	142,351	132,538	126,872
Sep-21	482,000	926,810	324,892	307,203	294,715
Oct-21	916,000	726,057	254,792	242,990	228,275
Nov-21	1,203,000	1,191,103	418,962	401,518	370,623
Dec-21	1,475,000	1,163,071	403,095	393,380	366,596
Production 2021 (ytd) (kWh)	11,708,000	10,341,917	3,597,229	3,467,693	3,276,995
Total Production (LTM) (kWh)	11,708,000	10,341,917	3,597,229	3,467,693	3,276,995
Capacity Factor (LTM)	26.24%				

B. Site Energy Production Graph

December-2021



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2022	Goldwind 6 Year Maintenance	~15	Z1
April-2022	Goldwind 6 Year Maintenance	~15	Z2
April-2022	Goldwind 6 Year Maintenance	~15	Z3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
12/11/2021	Weather Shutdown	Unplanned	7.24	Z1,Z2,Z3
12/24/2021	Plant Shutdown	Unplanned	10.26	Z1
12/24/2021	Plant Shutdown	Unplanned	11.35	Z2,Z3
12/28-29/2021	Weather Shutdown	Unplanned	10.00	Z1,Z2,Z3

F. Turbine Availability & Downtime*

Availability	This Month	Year To Date
Z1	99.94%	98.54%
Z2	100.00%	99.60%
Z3	100.00%	99.81%
Avg	99.98%	99.32%

Downtime (hr)	This Month	Year To Date
Z1	27.92	219.74
Z2	28.56	134.51
Z3	28.59	124.94
Total	85.07	479.19

G. Billed Data

Meter Reading (Date/Time)	12/17/2021 12:00 AM
Ball 1.0 Production (This Period)	1,431,308 kWh
Ball 1.0 Consumption (This Period)	784 kWh
Billed kWh	1,430,524 kWh
Next Meter Reading	1/20/2022 12:00 AM

H. Report Notes and Comments

*March downtime and availability under further review.
**December 2021 Downtime and Availability numbers are pending review and will be confirmed in the January 2022 report.