


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Dec-20	537,000	478,426
Jan-21	455,000	312,598
Feb-21	478,000	404,742
Mar-21	422,000	513,464
Apr-21	499,000	370,891
May-21	318,000	262,656
Jun-21	222,000	267,226
Jul-21	201,000	157,870
Aug-21	211,000	138,271
Sep-21	182,000	352,762
Oct-21	341,000	280,589
Nov-21	445,000	429,438
Dec-21	537,000	446,947
Production 2021 (ytd) (kWh)	4,311,000	3,937,454
Total Production (kWh)*	4,311,000	3,937,454
Capacity Factor*	29.97%	

*Value calculated over the last 12 months

B. Site Energy Production Graph

December-2021



Monthly Report
December-2021

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2022	Goldwind 4 Year Maintenance	~15	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
12/11/2021	Weather Shutdown	Unplanned	7.34	W1
12/28-29/2021	Weather Shutdown	Unplanned	8.39	W1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.96%
Downtime (hr)	This Month	Year To Date
W1	15.73	86.43

G. Billed Data

Meter Reading (Date/Time)	12/1/2021 12:00 AM
Meter To Date Produced	14,796,843 kWh
Meter To Date Consumed	69,016 kWh
Last Reading Produced	14,372,702 kWh
Last Reading Consumed	68,216 kWh
Billed kWh	423,341 kWh
Next Meter Reading	1/1/2022 12:00 AM

H. Report Notes and Comments

*December 2021 Downtime and Availability numbers are pending review and will be confirmed in the January 2022 report.