



Monthly Report
December-2021




A. Site Energy Production Summary

	Energy Production (kWh)					
	Site		By Turbine			
	Expected Production	Actual Production	WTG A	WTG B	WTG C	
Dec-20	1,278,858	1,465,048	488,349	488,349	488,349	**
Jan-21	1,332,437	995,915	331,972	331,972	331,972	**
Feb-21	1,157,019	1,160,396	386,799	386,799	386,799	**
Mar-21	1,242,761	1,601,636	533,879	533,879	533,879	**
Apr-21	1,447,248	1,114,956	371,652	371,652	371,652	**
May-21	1,010,966	876,324	292,108	292,108	292,108	**
Jun-21	668,411	811,402	270,467	270,467	270,467	**
Jul-21	638,097	457,358	152,453	152,453	152,453	**
Aug-21	577,992	450,170	150,057	150,057	150,057	**
Sep-21	631,697	1,046,539	348,846	348,846	348,846	**
Oct-21	1,003,602	902,727	300,909	300,909	300,909	**
Nov-21	1,395,914	1,321,032	440,344	440,344	440,344	**
Dec-21	1,278,858	1,140,578	380,193	380,193	380,193	**
Production 2021 (ytd) (kWh)	12,384,999	11,879,034	3,959,678	3,959,678	3,959,678	
Total Production (kWh) (LTM)	12,384,999	11,879,034	3,959,678	3,959,678	3,959,678	
Capacity Factor (LTM)	30.13%					

B. Site Energy Production Graph

December-2021



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2022	Goldwind 10.5 Year Maintenance	~8	WTG A
April-2022	Goldwind 10.5 Year Maintenance	~8	WTG B
April-2022	Goldwind 10.5 Year Maintenance	~8	WTG C

E. Actual Maintenance Events***

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime***

Availability	This Month	Year To Date
WTG A		
WTG B		
WTG C		
Avg		
Downtime (hr)	This Month	Year To Date
WTG A		
WTG B		
WTG C		
Total		

G. Wind Speed & Capacity Factor****

Wind Speed (mph)	This Month	2021 Annual
WTG A		
WTG B		
WTG C		
Estimated	14.23	13.39
Capacity Factor (%)	This Month	2021 Annual
WTG A	34.07%	
WTG B	34.07%	
WTG C	34.07%	
Low Estimate	37.80%	28.72%

H. Report Notes and Comments

**Production read from the meter due to communication issues and will be updated if SCADA data becomes available. Total metered production divided to estimate per turbine total.
***Downtime and Availability pending data availability. One Energy and Goldwind Maintenance duration to be updated pending data availability.
****Wind speed pending data availability. Capacity factors estimated based on metered production.