


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	V1	V2
Feb-21	737,000	766,729	389,871	376,858
Mar-21	777,000	939,050	475,834	463,216
Apr-21	722,000	668,188	334,264	333,924
May-21	564,000	507,392	250,537	256,855
Jun-21	422,000	431,379	211,027	220,352
Jul-21	351,000	280,633	134,016	146,617
Aug-21	303,000	269,721	132,186	137,535
Sep-21	431,000	616,679	299,115	317,564
Oct-21	674,000	503,743	250,852	252,891
Nov-21	796,000	791,404	397,996	393,408
Dec-21	820,000	763,656	384,433	379,223
Jan-22	931,000	817,296	405,482	411,814
Feb-22	737,000	838,853	421,431	417,422
Production 2022 (ytd) (kWh)	1,668,000	1,656,149	826,913	829,236
Total Production (LTM) (kWh)	7,528,000	7,427,994	3,697,173	3,730,821
Capacity Factor (LTM)	28.26%			

B. Site Energy Production Graph

February-2022



Monthly Report

February-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-22	Goldwind 3.5 Year Maintenance	~8	V1
April-22	Goldwind 3.5 Year Maintenance	~8	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
2/9/2022-2/10/2022	Fault	Unplanned	16.22	V1
2/17/2022-2/19/2022	Weather Shutdown	Unplanned	39.68	V1
2/17/2022-2/19/2022	Weather Shutdown	Unplanned	39.47	V2
2/24/2022-2/25/2022	Weather Shutdown	Unplanned	19.68	V1
2/24/2022-2/25/2022	Weather Shutdown	Unplanned	19.37	V2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
V1	97.48%	98.72%
V2	100.00%	100.00%
Avg	98.74%	99.36%

Downtime (hr)	This Month	Year To Date
V1	76.29	118.69
V2	58.84	100.59
Total	135.13	219.28

G. Billed Data

Meter Reading (Date/Time)	3/1/2022 12:00 AM
Meter To Date Produced	25,164,347 kWh
Meter To Date Consumed	64,276 kWh
Last Reading Produced	24,348,840 kWh
Last Reading Consumed	63,346 kWh
Billed kWh	814,577 kWh
Next Meter Reading	4/1/2022 12:00 AM

H. Report Notes and Comments

*February 2022 Downtime and Availability numbers are pending review and will be confirmed in the March 2022 report.