



HARPSTER WIND PROJECT


Harpster, OH

A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Feb-21	372,000	359,816
Mar-21	417,000	441,144
Apr-21	399,000	331,073
May-21	311,000	211,014
Jun-21	228,000	199,146
Jul-21	179,000	117,480
Aug-21	157,000	116,887
Sep-21	224,000	257,547
Oct-21	338,000	223,963
Nov-21	402,000	354,559
Dec-21	403,000	348,906
Jan-22	460,000	378,784
Feb-22	372,000	422,162
Production 2022 (ytd) (kWh)	832,000	800,946
Total Production (kWh) (LTM)	3,890,000	3,402,665
Capacity Factor (LTM)	25.90%	

B. Site Energy Production Graph

February-2022



Monthly Report February-2022



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2022	Goldwind 6 Year Maintenance	~15	H1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
2/17/2022-2/18/2022	Weather Shutdown	Unplanned	19.59	H1

F. Turbine Availability & Downtime*

Availability	This Month	Year To Date
H1	99.83%	99.90%
Downtime (hr)	This Month	Year To Date
H1	23.99	24.88

G. Billed Data

Meter Reading (Date/Time)	2/25/2022 12:00 AM
Meter To Date Produced	19,987,494 kWh
Meter To Date Consumed	66,962 kWh
Last Reading Produced	19,550,943 kWh
Last Reading Consumed	66,246 kWh
Billed kWh	435,835 kWh
Next Meter Reading	3/26/2022 12:00 AM

H. Report Notes and Comments

*February 2022 Downtime and Availability numbers are pending review and will be confirmed in the March 2022 report.