


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Feb-21	1,133,000	1,142,127	393,977	378,547	369,603
Mar-21	1,312,000	1,328,508	448,970	445,068	434,470
Apr-21	1,272,000	1,103,232	367,824	371,475	363,933
May-21	974,000	741,489	252,278	248,726	240,485
Jun-21	714,000	707,606	237,423	237,814	232,369
Jul-21	566,000	393,393	134,849	129,596	128,948
Aug-21	514,000	411,193	140,054	135,185	135,954
Sep-21	716,000	957,296	328,228	316,256	312,812
Oct-21	1,051,000	805,356	280,398	266,167	258,791
Nov-21	1,224,000	1,149,191	399,017	380,196	369,978
Dec-21	1,217,000	1,256,121	428,605	416,086	411,430
Jan-22	1,343,000	1,090,541	289,562	405,135	395,844
Feb-22	1,133,000	1,172,040	402,121	396,163	373,756
Production 2022 (ytd) (kWh)	2,476,000	2,262,581	691,683	801,298	769,600
Total Production (kWh)*	12,036,000	11,115,966	3,709,329	3,747,867	3,658,770
Capacity Factor*	28.20%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

February-2022



Monthly Report February-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2022	Goldwind 3.5 Year Maintenance	~8	WG 1
May-2022	Goldwind 3.5 Year Maintenance	~8	WG 2
May-2022	Goldwind 3.5 Year Maintenance	~8	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
2/2/2022-2/5/2022	Weather Shutdown	Unplanned	56.02	WG 1
2/2/2022-2/5/2022	Weather Shutdown	Unplanned	57.20	WG 2
2/2/2022-2/5/2022	Weather Shutdown	Unplanned	72.45	WG 3
2/6/2022	Fault	Unplanned	11.37	WG 3
2/8/2022	Weather Shutdown	Unplanned	4.30	WG 2
2/24/2022-2/25/2022	Weather Shutdown	Unplanned	16.15	WG 1
2/24/2022-2/25/2022	Weather Shutdown	Unplanned	16.23	WG 2
2/24/2022-2/26/2022	Weather Shutdown	Unplanned	19.59	WG 3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WG1	99.97%	94.91%
WG2	100.00%	100.00%
WG3	98.47%	99.24%
Avg	99.48%	98.05%

Downtime (hr)	This Month	Year To Date
WG1	72.38	211.48
WG2	77.73	89.95
WG3	103.41	115.83
Total	253.52	417.26

G. Billed Data

Meter Reading (Date/Time)	3/1/2022 12:00 AM
Meter To Date Produced	36,100,575 kWh
Meter To Date Consumed	137,756 kWh
Last Reading Produced	34,903,681 kWh
Last Reading Consumed	133,690 kWh
Billed kWh	1,192,828 kWh
Next Meter Reading	3/29/2022 12:00 AM

H. Report Notes and Comments

*February 2022 Downtime and Availability numbers are pending review and will be confirmed in the March 2022 report.