


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	V1	V2
Mar-21	777,000	939,050	475,834	463,216
Apr-21	722,000	668,188	334,264	333,924
May-21	564,000	507,392	250,537	256,855
Jun-21	422,000	431,379	211,027	220,352
Jul-21	351,000	280,633	134,016	146,617
Aug-21	303,000	269,721	132,186	137,535
Sep-21	431,000	616,679	299,115	317,564
Oct-21	674,000	503,743	250,852	252,891
Nov-21	796,000	791,404	397,996	393,408
Dec-21	820,000	763,656	384,433	379,223
Jan-22	931,000	817,296	405,482	411,814
Feb-22	737,000	838,853	421,431	417,422
Mar-22	777,000	942,768	455,809	486,959
Production 2022 (ytd) (kWh)	2,445,000	2,598,917	1,282,722	1,316,195
Total Production (LTM) (kWh)	7,528,000	7,431,712	3,677,148	3,754,564
Capacity Factor (LTM)	28.28%			

B. Site Energy Production Graph

March-2022



Monthly Report

March-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-22	Goldwind 3.5 Year Maintenance	~8	V1
April-22	Goldwind 3.5 Year Maintenance	~8	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
3/5/2022-3/6/2022	Turbine Fault	Unplanned	18.97	V1
3/28/2022	One Energy Semi-Annual Inspection	Unplanned	2.91	V1
3/28/2022	One Energy Semi-Annual Inspection	Unplanned	3.14	V2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
V1	97.45%	98.30%
V2	99.97%	99.99%
Avg	98.71%	99.14%

Downtime (hr)	This Month	Year To Date
V1	21.88	140.57
V2	3.35	103.94
Total	25.23	244.51

G. Billed Data

Meter Reading (Date/Time)	4/1/2022 12:00 AM
Meter To Date Produced	26,083,603 kWh
Meter To Date Consumed	65,307 kWh
Last Reading Produced	25,164,347 kWh
Last Reading Consumed	64,276 kWh
Billed kWh	918,225 kWh
Next Meter Reading	5/1/2022 12:00 AM

H. Report Notes and Comments