


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Mar-21	1,339,000	1,506,920	494,282	505,088	507,550
Apr-21	1,327,000	1,060,276	357,749	359,028	343,499
May-21	1,052,000	829,035	283,778	281,218	264,039
Jun-21	751,000	737,392	251,215	251,717	234,460
Jul-21	609,000	494,693	174,014	172,212	148,467
Aug-21	534,000	418,734	143,423	142,983	132,328
Sep-21	736,000	984,373	335,478	342,450	306,445
Oct-21	1,131,000	871,887	297,865	295,436	278,586
Nov-21	1,281,000	1,196,514	350,141	425,981	420,392
Dec-21	1,263,000	1,233,907	413,245	410,712	409,950
Jan-22	1,433,000	1,230,205	416,242	405,918	408,045
Feb-22	1,213,000	1,345,539	450,556	445,316	449,667
Mar-22	1,339,000	1,494,185	500,969	503,338	489,878
Production 2022 (ytd) (kWh)	3,985,000	4,069,929	1,367,767	1,354,572	1,347,590
Total Production (LTM) (kWh)	12,669,000	11,896,740	3,974,675	4,036,309	3,885,756
Capacity Factor (LTM)	30.18%				

B. Site Energy Production Graph

March-2022



Monthly Report
March-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration	Turbine
		(hr)	
September-2022	Goldwind 2 Year Maintenance	~15	L1
September-2022	Goldwind 2 Year Maintenance	~15	L2
September-2022	Goldwind 2 Year Maintenance	~15	L3

E. Actual Maintenance Events

Date	Event	Planned/ Unplanned	Duration (hrs)	Turbine
3/15/2022-3/16/2022	Goldwind 1.5 Year Maintenance	Planned	5.38	L2
3/16/2022	Goldwind 1.5 Year Maintenance	Planned	1.2	L1
3/16/2022	Goldwind 1.5 Year Maintenance	Planned	2.81	L3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	100.00%	100.00%
L2	100.00%	99.97%
L3	100.00%	100.00%
Avg	100.00%	99.99%

Downtime (hr)	This Month	Year To Date
L1	1.84	124.65
L2	6.02	136.99
L3	3.45	134.55
Total	11.31	396.19

G. Billed Data

Meter Reading (Date/Time)	3/26/2022 12:00 AM
Meter To Date Produced	19,507,041 kWh
Meter To Date Consumed	60,633 kWh
Last Reading Produced	18,258,697 kWh
Last Reading Consumed	58,304 kWh
Billed kWh	1,246,015 kWh
Next Meter Reading	4/27/2022 12:00 AM

H. Report Notes and Comments