


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	W1	W2	W3
Mar-21	1,134,000	1,290,867	437,185	424,582	429,100
Apr-21	1,176,000	752,920	257,397	246,019	249,504
May-21	927,000	646,261	217,827	210,837	217,597
Jun-21	634,000	571,998	186,211	188,627	197,160
Jul-21	527,000	318,063	107,885	100,155	110,023
Aug-21	449,000	324,019	109,256	105,233	109,530
Sep-21	610,000	740,131	243,253	241,498	255,380
Oct-21	990,000	693,360	241,616	219,829	231,915
Nov-21	1,123,000	976,482	349,225	311,053	316,204
Dec-21	1,153,000	1,088,213	372,080	354,578	361,555
Jan-22	1,306,000	845,320	315,868	177,718	351,734
Feb-22	1,137,000	1,182,964	407,437	382,881	392,646
Mar-22	1,134,000	1,341,048	444,624	443,527	452,897
Production 2022 (ytd) (kWh)	3,577,000	3,369,332	1,167,929	1,004,126	1,197,277
Total Production (kWh) (LTM)	11,166,000	9,480,779	3,252,679	2,981,955	3,246,145
Capacity Factor (LTM)	24.05%				

B. Site Energy Production Graph

March-2022



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2022	Goldwind 4.5 Year Maintenance	~8	W1
May-2022	Goldwind 4.5 Year Maintenance	~8	W2
May-2022	Goldwind 4.5 Year Maintenance	~8	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
3/5/2022-3/6/2022	Turbine Fault	Unplanned	19.5	W1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	97.38%	99.12%
W2	99.43%	99.77%
W3	99.92%	99.93%
Avg	98.91%	99.61%

Downtime (hr)	This Month	Year To Date
W1	19.50	234.23
W2	4.25	443.94
W3	0.58	226.05
Total	24.33	904.22

G. Billed Data

Meter Reading (Date/Time)	3/21/2022 12:00 AM
Meter To Date Produced	40,508,753 kWh
Meter To Date Consumed	122,235 kWh
Last Reading Produced	39,537,055 kWh
Last Reading Consumed	120,273 kWh
Billed kWh	969,736 kWh
Next Meter Reading	4/21/2022 12:00 AM

H. Report Notes and Comments