


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Mar-21	422,000	513,464
Apr-21	499,000	370,891
May-21	318,000	262,656
Jun-21	222,000	267,226
Jul-21	201,000	157,870
Aug-21	211,000	138,271
Sep-21	182,000	352,762
Oct-21	341,000	280,589
Nov-21	445,000	429,438
Dec-21	537,000	446,947
Jan-22	455,000	449,235
Feb-22	478,000	481,534
Mar-22	422,000	515,661
Production 2022 (ytd) (kWh)	1,355,000	1,446,430
Total Production (LTM) (kWh)	4,311,000	4,153,080
Capacity Factor (LTM)	31.61%	

B. Site Energy Production Graph

March-2022



Monthly Report
March-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2022	Goldwind 4.5 Year Maintenance	~8	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
3/18/2022	Grid Fault	Unplanned	7.90	W1
3/21/2022	Goldwind 4 Year Maintenance	Planned	3.86	W1
3/25/2022	One Energy Semi-Annual Inspection	Unplanned	2.28	W1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	100.00%
Downtime (hr)	This Month	Year To Date
W1	14.79	127.25

G. Billed Data

Meter Reading (Date/Time)	4/1/2022 12:00 AM
Meter To Date Produced	16,665,915 kWh
Meter To Date Consumed	73,640 kWh
Last Reading Produced	16,156,613 kWh
Last Reading Consumed	72,764 kWh
Billed kWh	508,426 kWh
Next Meter Reading	5/1/2022 12:00 AM

H. Report Notes and Comments