


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Apr-21	951,000	667,905	338,467	329,438
May-21	601,000	509,680	262,275	247,405
Jun-21	425,000	479,735	244,261	235,474
Jul-21	390,000	298,836	152,425	146,411
Aug-21	399,000	297,535	152,628	144,907
Sep-21	337,000	665,033	337,170	327,863
Oct-21	637,000	518,984	262,835	256,149
Nov-21	834,000	849,882	425,765	424,117
Dec-21	1,015,000	821,418	415,630	405,788
Jan-22	875,000	857,334	429,640	427,694
Feb-22	917,000	861,229	467,908	393,321
Mar-22	802,000	991,707	500,106	491,601
Apr-22	951,000	795,380	402,642	392,738
Production 2022 (ytd) (kWh)	3,545,000	3,505,650	1,800,296	1,705,354
Total Production (kWh) (LTM)	8,183,000	7,946,753	4,053,285	3,893,468
Capacity Factor (LTM)	30.24%			

B. Site Energy Production Graph

April-2022



Monthly Report

April-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2022	Goldwind 6.5 Year Maintenance	~8	W1
May-2022	Goldwind 6.5 Year Maintenance	~8	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.21%
W2	99.97%	99.99%
Avg	99.98%	99.60%

Downtime (hr)	This Month	Year To Date
W1	0.23	126.66
W2	2.48	170.18
Total	2.71	296.84

G. Billed Data

Meter Reading (Date/Time)	4/29/2022 12:00 AM
Meter To Date Produced	48,948,095 kWh
Meter To Date Consumed	95,687 kWh
Last Reading Produced	48,077,711 kWh
Last Reading Consumed	95,083 kWh
Billed kWh	869,780 kWh
Next Meter Reading	5/29/2022 12:00 AM

H. Report Notes and Comments

*April Downtime and Availability numbers and pending review and will be confirmed in the May 2022 report.