


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	W1	W2	W3
Apr-21	1,176,000	752,920	257,397	246,019	249,504
May-21	927,000	646,261	217,827	210,837	217,597
Jun-21	634,000	571,998	186,211	188,627	197,160
Jul-21	527,000	318,063	107,885	100,155	110,023
Aug-21	449,000	324,019	109,256	105,233	109,530
Sep-21	610,000	740,131	243,253	241,498	255,380
Oct-21	990,000	693,360	241,616	219,829	231,915
Nov-21	1,123,000	976,482	349,225	311,053	316,204
Dec-21	1,153,000	1,088,213	372,080	354,578	361,555
Jan-22	1,306,000	845,320	315,868	177,718	351,734
Feb-22	1,137,000	1,182,964	407,437	382,881	392,646
Mar-22	1,134,000	1,341,048	444,624	443,527	452,897
Apr-22	1,176,000	1,079,664	374,895	351,597	353,172
Production 2022 (ytd) (kWh)	4,753,000	4,448,996	1,542,824	1,355,723	1,550,449
Total Production (kWh) (LTM)	11,166,000	9,807,523	3,370,177	3,087,533	3,349,813
Capacity Factor (LTM)	24.88%				

B. Site Energy Production Graph

April-2022



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
December-2022	Goldwind 5 Year Maintenance	~15	W1
December-2022	Goldwind 5 Year Maintenance	~15	W2
December-2022	Goldwind 5 Year Maintenance	~15	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
4/26/2022	Goldwind 4.5 Year Maintenance	Planned	7.05	W1
4/26/2022	Goldwind 4.5 Year Maintenance	Planned	2.62	W2
4/26/2022	Goldwind 4.5 Year Maintenance	Planned	0.68	W3
4/28/2022	Goldwind 4.5 Year Maintenance	Planned	1.93	W3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	99.75%	99.28%
W2	100.00%	99.83%
W3	99.97%	99.94%
Avg	99.91%	99.68%

Downtime (hr)	This Month	Year To Date
W1	8.88	243.11
W2	2.62	446.56
W3	2.82	228.87
Total	14.32	918.54

G. Billed Data

Meter Reading (Date/Time)	4/21/2022 12:00 AM
Meter To Date Produced	41,859,115 kWh
Meter To Date Consumed	123,504 kWh
Last Reading Produced	40,508,753 kWh
Last Reading Consumed	122,235 kWh
Billed kWh	1,349,093 kWh
Next Meter Reading	5/21/2022 12:00 AM

H. Report Notes and Comments

*April 2022 Downtime and Availability numbers are pending review and will be confirmed in the May 2022 reports.