


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	V1	V2
May-21	564,000	507,392	250,537	256,855
Jun-21	422,000	431,379	211,027	220,352
Jul-21	351,000	280,633	134,016	146,617
Aug-21	303,000	269,721	132,186	137,535
Sep-21	431,000	616,679	299,115	317,564
Oct-21	674,000	503,743	250,852	252,891
Nov-21	796,000	791,404	397,996	393,408
Dec-21	820,000	763,656	384,433	379,223
Jan-22	931,000	817,296	405,482	411,814
Feb-22	737,000	838,853	421,431	417,422
Mar-22	777,000	942,768	455,809	486,959
Apr-22	722,000	794,963	403,811	391,152
May-22	564,000	648,467	329,704	318,763
Production 2022 (ytd) (kWh)	3,731,000	4,042,347	2,016,237	2,026,110
Total Production (LTM) (kWh)	7,528,000	7,699,562	3,825,862	3,873,700
Capacity Factor (LTM)	29.30%			

B. Site Energy Production Graph

May-2022



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-22	Goldwind 4 Year Maintenance	~15	V1
October-22	Goldwind 4 Year Maintenance	~15	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
5/13/2022	Goldwind 3.5 Year Basement Maintenenace	Planned	0.82	V1,V2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
V1	100.00%	98.98%
V2	99.97%	99.41%
Avg	99.99%	99.20%

Downtime (hr)	This Month	Year To Date
V1	4.23	147.30
V2	3.59	131.89
Total	7.82	279.19

G. Billed Data

Meter Reading (Date/Time)	6/1/2022 12:00 AM
Meter To Date Produced	27,485,819 kWh
Meter To Date Consumed	67,156 kWh
Last Reading Produced	26,854,117 kWh
Last Reading Consumed	66,078 kWh
Billed kWh	630,624 kWh
Next Meter Reading	7/1/2022 12:00 AM

H. Report Notes and Comments